

JCM Proposed Methodology Form

Cover sheet of the Proposed Methodology Form

Form for submitting the proposed methodology

Host Country	The Republic of Indonesia
Name of the methodology proponents submitting this form	Japan Pulp and Paper Company Limited Institute for Global Environmental Strategies (IGES)
Sectoral scope(s) to which the Proposed Methodology applies	1. Energy industries (renewable- / non-renewable sources)
Title of the proposed methodology, and version number	Installation of closed drain recovery system and utilization for boiler feed water, Version 01.0
List of documents to be attached to this form (please check):	<input type="checkbox"/> The attached draft JCM-PDD: <input type="checkbox"/> Additional information
Date of completion	28/11/2021

History of the proposed methodology

Version	Date	Contents revised
01.0	28/11/2021	First edition

A. Title of the methodology

Installation of closed drain recovery system and utilization for boiler feed water, Version 01.0

B. Terms and definitions

Terms	Definitions
Drain	Drain is a waste hot water which is trapped and condensed after waste steam at process of works is caught by steam trap.
Closed drain recovery system	Drain recovery system is an equipment which recovers drain with some heating energy and reuses for boiler feed water. Recovered drain is once stocked in tank before reuse. Closed drain recovery system has a tank with the lid. Drained water is kept at high temperature.
Opening drain recovery system	Opening drain recovery system has a tank without covering. Temperature of drained water is down to 100 °C or less because vapor of drained water is released to atmosphere.

C. Summary of the methodology

Items	Summary
<i>GHG emission reduction measures</i>	By installing a closed drain recovery system, boiler feed water is heated up. Consequently, fossil fuel consumption of boiler(s) is reduced, leading to the reduction of GHG emissions.
<i>Calculation of reference emissions</i>	Reference emissions are calculated using the following parameters: <ul style="list-style-type: none"> • Saving rate of boiler fuel consumption per degree of risen temperature for boiler feed water • Temperature of boiler feed water including both of makeup feed water and hot water recovered by the project closed drain recovery system • Reference temperature of boiler feed water including both of makeup feed water and hot water recovered by the project closed drain recovery system

	<ul style="list-style-type: none"> • Fossil fuel consumption of boiler(s) utilizing hot water recovered by the project closed drain recovery system • Net calorific value of fossil fuel consumed by boiler(s) • CO₂ emission factor of fossil fuel consumed by boiler(s)
<i>Calculation of project emissions</i>	Project emissions are not considered as a project closed drain recovery system does not utilize electricity and any fossil fuels.
<i>Monitoring parameters</i>	<ul style="list-style-type: none"> • Amount of the fossil fuel type consumed by boiler(s) utilizing hot water recovered by the project closed drain recovery system • Temperature of hot water recovered by the project closed drain recovery system • Temperature of boiler feed water including both of makeup feed water and hot water recovered drain water

D. Eligibility criteria

This methodology is applicable to projects that satisfy all of the following criteria.

Criterion 1	The project newly installs closed drain recovery system(s) to heat up boiler feed water.
Criterion 2	Project closed drain recovery system does not additionally utilize electricity and any fossil fuels.

E. Emission Sources and GHG types

Reference emissions	
Emission sources	GHG types
Fossil fuel(s) consumed by boiler(s) to generate the amount of heat recovered by a project closed drain recovery system	CO ₂
Project emissions	
Emission sources	GHG types
N/A	N/A

F. Establishment and calculation of reference emissions

F.1. Establishment of reference emissions

In this methodology, it is assumed that opening drain recovery system is set as the reference one, because in many factories in Indonesia, drain recovery system is not introduced or opening drain recovery system is applied. In case that an opening drain system is introduced, the temperature of recovered drain water is comparatively low, and the amount of boiler fuel is needed more than the case when a closed drain recover system is introduced.

In order to secure net emission reductions in this methodology, the reference emission is conservatively calculated in the following manners.

-Setting “temperature of makeup feed water into boiler(s)” as 30.3 °C based on the highest value in the monthly average atmospheric temperatures for 2 years (November, 2018- October, 2020) in Jakarta, Medan, Palembang, Balikpapan, Semarang, Denpasar, Cirebon, Serang, Tegal, Cilacap and Curag.

-Setting “Rate of decrease in boiler fuel consumption per degree rise in temperature of boiler feed water” as 0.0015 [dimensionless /ΔK] in case that boiler feed water is 20 °C. The saving rate at the temperature range of boiler feed water higher than 20 °C is slightly higher than 0.0015 [dimensionless /ΔK].

-Setting “reference temperature of boiler feed water including both of makeup feed water and hot water recovered by a project closed drain recovery system” as 100 [°C].

F.2. Calculation of reference emissions

$$RE_p = SRF_{boiler} \times \Delta T_{PJ,p} / (1 - SRF_{boiler} \times \Delta T_{PJ,p}) \times \sum_i FC_{PJ,i,p} \times NCV_{fuel,i,p} \times EF_{fuel,i,p}$$

$$\Delta T_{PJ,p} = TFW_{PJ,p} - TFW_{RE,p}$$

$$TFW_{RE,p} = \frac{TMW + R_{dw/mw,p} \times TDW_{RE}}{1 + R_{dw/mw,p}}$$

$$R_{dw/mw,p} = \frac{TFW_{PJ,p} - TMW}{TDW_{PJ,p} - TFW_{PJ,p}}$$

Where;

RE_p	:	Reference emissions during the period p [tCO ₂ /p]
i	:	Identification number of fossil fuel type consumed by boiler(s) utilizing hot water recovered by the project closed drain recovery system [dimensionless]
SRF_{boiler}	:	Rate of decrease in boiler fuel consumption per degree rise in temperature of boiler feed water [dimensionless /ΔK]
$\Delta T_{PJ,p}$:	Risen temperature of boiler feed water heated by the project closed drain recovery system during the period p [ΔK]
$TFW_{PJ,p}$:	Temperature of boiler feed water including both of makeup feed water and hot water recovered by the project closed drain recovery system during the period p [degrees C]
$TFW_{RE,p}$:	Reference temperature of boiler feed water including both of makeup feed water and hot water recovered by reference drain recovery system during the period p [degrees C]
$FC_{PJ,i,p}$:	Amount of fossil fuel type i consumed by boiler(s) utilizing hot water recovered by the project closed drain recovery system during period p [mass or volume/p]
$NCV_{fuel,i,p}$:	Net calorific value of fossil fuel type i consumed by boiler(s) [GJ/mass or volume unit]
$EF_{fuel,i,p}$:	CO ₂ emission factor of fossil fuel type i consumed by boiler(s) [tCO ₂ /GJ]
$R_{dw/mw,p}$:	The ratio of flow rate of hot water recovered by the project closed drain recovery system to flow rate of makeup feed water during the period p [dimensionless]
TDW_{RE}	:	Temperature of hot water recovered by reference drain recovery system [degrees C]
TMW	:	Temperature of makeup feed water into boiler(s) [degrees C]
$TDW_{PJ,p}$:	Temperature of hot water recovered by the project drain recovery system during the period p [degrees C]

Note) In case that $TDW_{PJ,p}$ is not monitored, a value of 100 [°C] is applied to $TFW_{RE,p}$ in conservative manner.

G. Calculation of project emissions

Project emissions are not assumed in the methodology as a project closed drain recovery system does not utilize electricity and any fossil fuels, which is prescribed in the eligibility criterion 2. Therefore, the following formula is used to express the project emissions:

$$PE_p = 0$$

H. Calculation of emissions reductions

$$ER_p = RE_p - PE_p$$

Where

ER_p : Emission reductions during the period p [tCO₂/p]

RE_p : Reference emissions during the period p [tCO₂/p]

PE_p : Project emissions during the period p [tCO₂/p]

I. Data and parameters fixed *ex ante*

The source of each data and parameter fixed *ex ante* is listed as below.

Parameter	Description of data	Source
SRF_{boiler}	Rate of decrease in boiler fuel consumption per degree rise in temperature of boiler feed water [dimensionless /ΔK] For conservative default value, a value of 0.0015 may be applied based on the case that boiler feed water is 20 °C, because the saving rate at the temperature range of boiler feed water higher than 20 °C is slightly higher than 0.0015 [dimensionless /K].	Figure 3.5.1 “Relationship between feed water temperature and saving rate of boiler fuel consumption” in “Nomograph collection for energy saving in boiler” published by Japan Boiler Association
$NCV_{fuel,i,p}$	Net calorific value of fossil fuel type i consumed by boiler(s) [GJ/mass or volume]	In the order of preference: a) values provided by the fuel supplier; b) measurement by the project participants; c) regional or national

		default values published by the Ministry of Energy and Mineral Resources, Indonesia; d) IPCC default values provided in table 1.2 of Ch.1 Vol.2 of 2006 IPCC Guidelines on National GHG Inventories. Lower value is applied.
$EF_{fuel,i,p}$	CO ₂ emission factor of fossil fuel type i consumed by boiler(s) [tCO ₂ /GJ]	In the order of preference: a) values provided by the fuel supplier; b) measurement by the project participants; c) regional or national default values published by the Ministry of Energy and Mineral Resources, Indonesia; d) IPCC default values provided in table 1.4 of Ch.1 Vol.2 of 2006 IPCC Guidelines on National GHG Inventories. Lower value is applied.
TDW_{RE}	Temperature of hot water recovered by reference drain recovery system [degrees C] A value of 100 °C is applied, because reference drain recovery system is assumed to be an opening one.	Default value set in the methodology
$TFW_{RE,p}$	Reference temperature of boiler feed water including both of makeup feed water and hot water recovered by the project closed drain recovery system [degrees C] (In case that $TDW_{PJ,p}$ is not monitored, a value of	Default value

	100 °C is applied in conservative manner.)	
<i>TMW</i>	<p>Temperature of makeup feed water into boiler(s) [degrees C]</p> <p>A value of 30.3 [degrees C] is applied in conservative manner based on the highest value in the monthly average atmospheric temperatures for 2 years (November 2018 – October 2020) in Jakarta, Medan, Palembang, Barikpapan, Semarang, Denpasar, Cirebon, Serang, Tegal, Cilacap and Curag.</p>	<p>Climate data tool in the world (ClimatView Monthly statistic) by Japan Meteorological Agency</p>