Joint Crediting Mechanism Approved Methodology ID_AM015 "Energy Saving by Introduction of High Efficiency Once-through Boiler"

A. Title of the methodology

Energy Saving by Introduction of High Efficiency Once-through Boiler, Version.01.0

B. Terms and definitions

Terms	Definitions
Once-through boiler	A once-through boiler is a boiler without recirculation
	where water flows through the economizer, furnace wall,
	and evaporating and superheating tubes, sequentially.
	Once-through boiler is used to supply heat in factory and
	commercial facility.
Periodical check	Periodical check is a scheduled examination of the project
	boiler conducted by manufacturer or agent who is
	authorized by the manufacturer in order to maintain
	performance of the boiler.
Boiler efficiency	Boiler efficiency is the percentage of heat quantity used to
	generate steam against total heat quantity provided by a
	fuel.
Blow flow rate	Blow flow rate is the percentage of boiler blow volume
	against feed water volume to prevent condensation of
	water in the boiler. The rate will be reduced by introducing
	water purification and demineralization system such as
	Reverse Osmosis (RO)
Fuel switching	Fuel switching involves the change of fuel from the one
	with higher GHG emissions factor to lower GHG emission
	factor (i.e. from coal to natural gas).

C. Summary of the methodology

|--|

GHG emission reduction	This methodology involves the installation of high efficiency
measures	once-through boiler. Compared with the fire tube boilers
	which dominate Indonesian market, the efficiency of
	once-through boiler is higher and fuel consumption is less. Thus
	the introduction of once-through boiler will contribute to the
	GHG emission reductions.
Calculation of reference	Reference emissions are calculated based on the efficiency of
emissions	the boiler currently dominant in the Indonesian market.
	Conservative estimation of reference emissions is made by
	taking into consideration of the following points: (i) lower CO ₂
	emission factor is selected from IPCC guideline with regard to
	the fuel used in reference boiler, and (ii) higher efficiency is
	applied for the reference boiler especially in low load range.
Calculation of project	Project emissions are calculated on the basis of monitored fuel
emissions	consumption and emission factor of the fuel of the project
	boiler.
Monitoring parameters	- The amount of fuel consumption

D. Eligibility criteria		
This methodology is applicable to projects that satisfy all of the following criteria.		
Criterion 1	The project boiler is a once-through boiler with a rated capacity of 7 ton/hour	
	per unit or less (equivalent evaporation)	
Criterion 2	Periodical check and maintenance by the manufacturer of boiler or authorized	
	agent is implemented in accordance with the manufacturer's requirement.	
Criterion 3	Appropriate water purification/demineralization system such as Reverse	
	Osmosis (RO) membrane treatment is installed.	

E. Emission Sources and GHG types

Reference emissions		
Emission sources	GHG types	
Fuel consumption by reference boiler	CO_2	
Project emissions		
Emission sources GHG types		

Fuel consumption by project boiler	CO_2
------------------------------------	--------

F. Establishment and calculation of reference emissions

F.1. Establishment of reference emissions

Reference emissions are calculated based on the efficiency of the fire tube boilers which dominates the Indonesian boiler market for industries. The fuel types widely used in Indonesia are coal, followed by oil (heavy fuel oil and diesel). In order to ensure the net emission reductions, the higher efficiency of the reference boiler (89%) is adopted to calculate the reference emissions. In addition, 1) compared with reference boiler (oil and gas type), once-through boiler (project boiler) can maintain high efficiency even at low load range, which improves the operating efficiency of project boiler and 2) compared with reference boiler (coal), operational efficiency of the project boiler is higher due to better combustion control, which also ensures the net emission reductions. Besides, to calculate the reference emissions conservatively, lower CO_2 emission factor stated in 2006 IPCC guidelines is adopted to secure the net emission reductions.

Introduction of water purification/demineralization system such as the RO also enables the reduction of blow flow of boiler water, which can save fuel consumption compared with the conventional water treatment system such as softener. The amount of fuel saving is inversely proportional to the boiler blow flow rate.

F.2. Calculation of reference emissions

	$RE_{p} = \sum_{i} \sum_{j} \left(FC_{p,i,j,PJ} \times NCV_{i,j,PJ} \times EF_{RE} \times \frac{\eta_{i,PJ}}{\eta_{RE}} \times \frac{100 - BF_{i,PJ}}{100 - BF_{RE}} \right)$
REp	: Reference emissions during the period p [tCO ₂ /p]
FC _{p,i,j,PJ}	: The amount of fuel consumption of project boiler i for the fuel type j during the
	period <i>p</i> [mass or volume unit/p]
NCV _{i,j,PJ}	: Net calorific value of fuel used by project boiler i for the fuel type j [GJ/mass or
	volume unit]
EF _{RE}	: CO ₂ emission factor of fuel used by reference boiler [tCO ₂ /GJ]
$\eta_{i,PJ}$: Efficiency of project boiler <i>i</i> [dimensionless]
η_{RE}	: Efficiency of reference boiler [dimensionless]
$BF_{i,PJ} \\$: Blow flow rate setting of project boiler <i>i</i> [%]

 BF_{RE} : Blow flow rate setting of reference boiler [%]

G. Calculation of project emissions

$$PE_{p} = \sum_{i} \sum_{j} (FC_{p,i,j,PJ} \times NCV_{i,j,PJ} \times EF_{i,j,PJ})$$

PEp	: Project emissions during the period p [tCO ₂ /p]
$FC_{p,i,j,PJ}$: The amount of fuel consumption of project boiler i for the fuel type j during the
	period <i>p</i> [mass or volume unit/p]
NCV _{i,j,PJ}	: Net calorific value of fuel used by project boiler i for the fuel type j [GJ/mass or
	volume unit]
$\mathrm{EF}_{\mathrm{i},\mathrm{j},\mathrm{PJ}}$: CO ₂ emission factor of fuel used by project boiler <i>i</i> for the fuel type <i>j</i> [tCO ₂ /GJ]

H. Calculation of emissions reductions

	$ER_{p} = RE_{p} - PE_{p}$
ER_p	: Emission reductions during the period p [tCO ₂ /p]
RE_p	: Reference emissions during the period p [tCO ₂ /p]
PE_p	: Project emissions during the period p [tCO ₂ /p]

I. Data and parameters fixed *ex ante*

The source of each data and parameter fixed *ex ante* is listed as below.

Parameter	Description of data	Source
NCV _{i,j,PJ}	Net calorific value of fuel used by	(1) Net calorific value (lower heating
	project boiler <i>i</i> for the fuel type <i>j</i>	value) provided by fuel supplier or
	[GJ/mass or volume unit]	boiler manufacturer, (2) IPCC default
		values at the lower limit in Table 1.2 of
		Chapter 1 of Vol. 2 of the "2006 IPCC
		Guidelines for National GHG
		Inventories" (when (1) is not available,
		apply (2))

EF _{i,j,PJ}	CO ₂ emission factor of fuel used by	IPCC default value in Table 1.4 of
	the project boiler i for the fuel type j	Chapter 1 of Vol. 2 from "2006 IPCC
	[tCO ₂ /GJ]	Guidelines for National Greenhouse
		Gas Inventories"
EF _{RE}	CO ₂ emission factor of fuel used by	IPCC default value at the lower limit in
	the reference boiler [tCO ₂ /GJ]	Table 1.4 of Chapter 1 of Vol. 2 from
	In case the project boiler replaces	"2006 IPCC Guidelines for National
	the existing boiler or the planned	Greenhouse Gas Inventories"
	boiler whose plan is once approved	
	officially such as with boiler	
	installation permit or environmental	
	impact assessment, CO ₂ emission	
	factor of the fuel used by the	
	existing or planned boiler is	
	applied.	
	Otherwise, the value of the fuel	
	used by the project boiler i is	
	applied.	
$\eta_{i,PJ}$	Efficiency of project boiler <i>i</i>	Specifications of the project boiler or
	[dimensionless]	factory test data of the project boiler by
		the manufacturer
η_{RE}	Efficiency of reference boiler	Default value in the methodology
	[dimensionless]	
	The default value of η_{RE} is set as	
	0.89.	
BF _{i,PJ}	Blow flow rate setting of the project	Blow flow rate setting specified in the
	boiler <i>i</i> [%]	boiler water treatment program for a
		water purification/demineralization
		system such as RO based on the test
		result
BF _{RE}	Blow flow rate setting of reference	Blow flow rate specified in the boiler
	boiler [%]	water treatment program for a water
		softener based on the test result

History of the document

Version	Date	Contents revised
01.0	10 July 2018	JC8, Annex 4
		Initial approval.