

## Joint Crediting Mechanism Approved Methodology VN\_AM003

### “Improving the energy efficiency of commercial buildings by utilization of high efficiency equipment”

#### A. Title of the methodology

Improving the energy efficiency of commercial buildings by utilization of high efficiency equipment, Version 01.0

#### B. Terms and definitions

Terms	Definitions
High efficiency equipment	Building facility equipment listed in Table 1 of the eligibility criterion 1.
Reference equipment	Equipment whose output is replaced/substituted by the project.
Coefficient of Performance (COP)	<p>For the purpose of this methodology, COP is defined as a ratio of heat supplied to the amount of energy consumed by a chiller or heat pump, and it is defined by using following formula:</p> $\text{COP} = \text{Q/W}$ <p>Where:</p> <p>Q: Amount of heat supplied by a chiller or a heat pump</p> <p>W: Electric power consumed by a chiller or a heat pump</p>

#### C. Summary of the methodology

Items	Summary
<i>GHG emission reduction measures</i>	Reduction of electricity and fossil fuel consumed by existing facilities is achieved by replacing or substituting these facilities with high efficiency equipment defined in Table 1 of the eligibility criterion 1.
<i>Calculation of reference emissions</i>	Reference emissions are calculated by multiplying electricity and fossil fuel consumption of the project by the ratio of

	<p>efficiency of reference and project equipment, and emission factors of electricity and fossil fuel.</p> <p>For the installation of high efficiency lighting, reference emissions are calculated using rated electricity consumption of the lighting multiplied by operation hours.</p>
<i>Calculation of project emissions</i>	Project emissions are calculated based on monitored electricity and fossil fuel consumption in the project.
<i>Monitoring parameters</i>	<p>Electricity and fossil fuel consumption of the high efficiency equipment</p> <p>Operating hours of the high efficiency equipment and auxiliary equipment, where applicable</p>

## D. Eligibility criteria

This methodology is applicable to projects that satisfy all of the following criteria.

<p>Criterion 1</p>	<p>The project involves implementation of one or more energy efficiency measures categorized in Table 1 by using high efficiency equipment at an existing facility.</p> <p>Projects involving installation of high efficiency lighting need to be coupled with another energy saving measure(s) in order to be eligible under this methodology.</p> <p>High efficiency equipment introduced by the project replaces the existing equipment or substitutes the output of the existing equipment, and it is included in the applicable technologies as shown in Table 1:</p> <p>Table 1 Applicable Technologies</p> <table border="1" data-bbox="411 824 1359 1339"> <thead> <tr> <th data-bbox="411 824 483 891">No</th> <th data-bbox="491 824 738 891">Energy efficiency measures</th> <th data-bbox="746 824 1359 891">Applicable technologies and their criteria</th> </tr> </thead> <tbody> <tr> <td data-bbox="411 891 483 1099">1</td> <td data-bbox="491 891 738 1099">Energy efficiency improvement by reducing fossil fuel consumption</td> <td data-bbox="746 891 1359 1099">High efficiency boiler with the following features: - Energy efficiency is greater or equal to 93% (e.g. small once-through boiler); - Equipped with automatic unit number control device; and - Individual performance test report is provided.</td> </tr> <tr> <td data-bbox="411 1099 483 1267">2</td> <td data-bbox="491 1099 738 1267">Fuel switch to electricity and/or efficiency improvement</td> <td data-bbox="746 1099 1359 1267">Heat recovery heat pump using electricity, which generates both cooling and heating energy (temperature of hot water <math>\geq 80^{\circ}\text{C}</math>) and uses non-HFC refrigerant with zero Ozone Depletion Potential (ODP)</td> </tr> <tr> <td data-bbox="411 1267 483 1339">3</td> <td data-bbox="491 1267 738 1339">Installation of high efficiency lighting</td> <td data-bbox="746 1267 1359 1339">LED lighting</td> </tr> </tbody> </table>	No	Energy efficiency measures	Applicable technologies and their criteria	1	Energy efficiency improvement by reducing fossil fuel consumption	High efficiency boiler with the following features: - Energy efficiency is greater or equal to 93% (e.g. small once-through boiler); - Equipped with automatic unit number control device; and - Individual performance test report is provided.	2	Fuel switch to electricity and/or efficiency improvement	Heat recovery heat pump using electricity, which generates both cooling and heating energy (temperature of hot water $\geq 80^{\circ}\text{C}$ ) and uses non-HFC refrigerant with zero Ozone Depletion Potential (ODP)	3	Installation of high efficiency lighting	LED lighting
No	Energy efficiency measures	Applicable technologies and their criteria											
1	Energy efficiency improvement by reducing fossil fuel consumption	High efficiency boiler with the following features: - Energy efficiency is greater or equal to 93% (e.g. small once-through boiler); - Equipped with automatic unit number control device; and - Individual performance test report is provided.											
2	Fuel switch to electricity and/or efficiency improvement	Heat recovery heat pump using electricity, which generates both cooling and heating energy (temperature of hot water $\geq 80^{\circ}\text{C}$ ) and uses non-HFC refrigerant with zero Ozone Depletion Potential (ODP)											
3	Installation of high efficiency lighting	LED lighting											
<p>Criterion 2</p>	<p>If the existing equipment is a chiller containing CFCs, HFCs, or HCFCs and is removed due to the project, a plan to prevent release of refrigerant used for the existing chiller into the atmosphere is prepared. Execution of the prevention plan is checked at the time of verification, in order to confirm that the refrigerant used for the existing chiller is not released to the air.</p>												
<p>Criterion 3</p>	<p>High efficiency equipment in the project guarantees a better performance than the reference equipment for a minimum of one year.</p> <p>The performance level can be confirmed by comparing the efficiency or rated electricity consumption between the high efficiency equipment and the reference equipment, with an evidence of either a manufacturer's performance guarantee or energy saving company's (ESCO) energy saving guarantee of high efficiency equipment. Where such evidence is not available for the reference equipment, high efficiency equipment in the project guarantees a better performance than the default efficiency values provided in the methodology.</p>												

## E. Emission Sources and GHG types

Reference emissions	
Emission sources	GHG types
Fossil fuel consumption by the reference equipment	CO <sub>2</sub>
Electricity consumption by the reference equipment	CO <sub>2</sub>
Project emissions	
Emission sources	GHG types
Fossil fuel consumption by the high efficiency equipment	CO <sub>2</sub>
Electricity consumption by the high efficiency equipment	CO <sub>2</sub>
Electricity consumption by the auxiliary equipment for the high efficiency equipment	CO <sub>2</sub>

## F. Establishment and calculation of reference emissions

### F.1. Establishment of reference emissions

Reference emissions are calculated by multiplying electricity and fossil fuel consumption of the project by the ratio of efficiency of reference and project equipment, and emission factors of electricity and fossil fuel. Individual electricity and fossil fuel consumption are derived from monitored fuel and electricity consumption by the high efficiency equipment. Below are typical examples of reference equipment replaced or substituted by high efficiency equipment.

	Energy efficiency measures	Project equipment	Typical examples of reference equipment
1	Energy efficiency improvement by reducing fossil fuel consumption	High efficiency boiler	Boiler
2	Fuel switch to electricity and/or efficiency improvement	Heat recovery heat pump	Boiler Chiller
3	Installation of high efficiency lighting	LED lighting	Halogen Fluorescent

The methodology ensures net emission reductions by the followings:

- 1) Adopting conservative default efficiency values for calculation of reference emissions
  - Boilers: applying CDM default efficiency for new boilers;

- Chillers: design efficiency of models sold by dominant manufacturers in the chiller market in Vietnam

## 2) Implementation of multiple measures

Among the three measures introduced in this methodology, one measure (installation of high efficiency lighting) may have a possibility where the calculation result will not demonstrate net emission reductions due to the way the equation is formulated. In order to ensure the net emission reductions, the methodology requires to implement together with other energy efficiency measure(s) stated in table 1 under the eligibility criteria.

## F.2. Calculation of reference emissions

Reference emissions are calculated by the following equation:

$$RE_p = \frac{\sum_i EC_{REF,i,p}}{1,000} \times EF_{CO_2,ELEC} + \sum_i (FC_{REF,i,p} \times EF_{CO_2}) \quad (1)$$

Where

$RE_p$	Reference emissions during the period $p$ [tCO <sub>2</sub> /p]
$EC_{REF,i,p}$	Electricity consumed during the period $p$ by reference equipment corresponding to measure $i$ introduced in the project [kWh/p]
$EF_{CO_2,ELEC}$	CO <sub>2</sub> emission factor of electricity consumed [tCO <sub>2</sub> /MWh]
$FC_{REF,i,p}$	Fossil fuel consumed during the period $p$ by reference equipment, corresponding to measure $i$ introduced in the project [L/p].
$EF_{CO_2}$	CO <sub>2</sub> emission factor of fossil fuel [tCO <sub>2</sub> /L]
$i$	Type of measure

### Measure 1: High efficiency boiler

$$FC_{REF,1,p} = \sum_i FC_{PJ1,i,p} \times \frac{\eta_{PJ1,i}}{\eta_{REF1,i}} \quad (2)$$

Where

$FC_{REF,1,p}$	Total fossil fuel that would have been consumed during the period $p$ by the reference equipment, replaced/substituted by the high efficiency equipment introduced in the project categorized as measure 1 [L/p]
$FC_{PJ1,i,p}$	Fossil fuel consumed during the period $p$ by the high efficiency equipment $i$

introduced in the project categorized as measure 1 [L/p]

$\eta_{PJ,i}$  Energy efficiency of the equipment  $i$  introduced in the project [dimensionless]

$\eta_{REF,i}$  Energy efficiency of the reference equipment, replaced/substituted by the equipment  $i$  introduced in the project [dimensionless]

### Measure 2: Heat recovery heat pump

$$FC_{REF,2,p} = \sum_i \frac{EC_{PJ2,i,p}}{ECR_i} \times H_i \times DC_i \quad (3)$$

$$EC_{REF,2,p} = \sum_i \frac{EC_{PJ2,i,p}}{ECR_i} \times \frac{CH_i}{COP_i} \quad (4)$$

Where

$FC_{REF,2,p}$  Total fossil fuel that would have been consumed during the period  $p$  by the reference equipment, replaced/substituted by the high efficiency equipment in the project categorized as measure 2 [L/p]

$EC_{PJ2,i,p}$  Electricity consumed during the period  $p$  by the high efficiency equipment  $i$  in the project categorized as measure 2 [kWh/p]

$ECR_i$  Rated electricity consumption of the high efficiency equipment  $i$  introduced in the project [kW]

$H_i$  Rated heating capacity of the high efficiency equipment  $i$  in the project [kW]

$DC_i$  Unit fuel consumption rate of the reference equipment that are replaced/substituted by the equipment  $i$  in the project [L/kWh]

$EC_{REF,2,p}$  Total electricity that would have been consumed during the period  $p$  by the reference equipment, replaced/substituted by the high efficiency equipment introduced in the project categorized as measure 2 [kWh/p]

$CH_i$  Rated cooling capacity of the high efficiency equipment  $i$  introduced in the project [kW]

$COP_i$  Efficiency of reference cooling equipment replaced/substituted by the equipment  $i$  introduced in the project [dimensionless]

### Measure 3: LED lighting

$$EC_{REF,3,p} = \sum_i ECR_{REF3,i} \times t_{i,p} \quad (5)$$

Where

$EC_{REF,3,p}$  Total electricity that would have been consumed during the period  $p$  by the reference equipment, replaced/substituted by the high efficiency equipment

	introduced in the project categorized as measure 3 [kWh/p]
$ECR_{REF3,i}$	Rated electricity consumption of the reference equipment $i$ , replaced by the high efficiency equipment $i$ in the project categorized as measure 3 [kW]
$t_{i,p}$	Operating hours of the high efficiency equipment $i$ during the period $p$ in the project categorized as measure 3 [hr/p]

## G. Calculation of project emissions

Project emissions are calculated as a sum of emissions from electricity and fossil fuel consumption in the project. The emission from electricity consumption is calculated by multiplying electricity consumed by the project ( $EC_{PJ,i,p}$ ) by the CO<sub>2</sub> emission factor of electricity ( $EF_{CO_2,ELEC}$ ). The emission from fuel consumption is calculated by multiplying fuel consumed by the project ( $FC_{PJ,i,p}$ ) by the emission factor of the fuel ( $EF_{CO_2}$ ).

$$PE_p = \frac{\sum_i EC_{PJ,i,p}}{1,000} \times EF_{CO_2,ELEC} + \sum_i (FC_{PJ,i,p} \times EF_{CO_2}) \quad (6)$$

Where

$PE_p$	Project emissions during the period $p$ [tCO <sub>2</sub> /p]
$EC_{PJ,i,p}$	Total electricity consumed by the high efficiency equipment by measure $i$ introduced in the project during the period $p$ [kWh/p]
$EF_{CO_2,ELEC}$	CO <sub>2</sub> emission factor of the electricity consumed [tCO <sub>2</sub> /MWh]
$FC_{PJ,i,p}$	Total fossil fuel consumed by the high efficiency equipment by measure $i$ introduced in the project during the period $p$ [L/p]
$EF_{CO_2}$	CO <sub>2</sub> emission factor of fossil fuel [tCO <sub>2</sub> /L]
$i$	Type of measure

### Measure 1: High efficiency boiler

$$FC_{PJ,1,p} = \sum_i FC_{PJ1,i,p} \quad (7)$$

Where

$FC_{PJ,1,p}$	Total fossil fuel consumed during the period $p$ by the high efficiency equipment introduced in the project categorized as measure 1 [L/p]
$FC_{PJ1,i,p}$	Fossil fuel consumed during the period $p$ by the high efficiency equipment $i$ introduced in the project categorized as measure 1 [L/p]

**Measure 2: Heat recovery heat pump**

$$EC_{PJ,2,p} = \sum_i (EC_{PJ2,i,p} + ECA_i \times t_p) \quad (8)$$

Where

$EC_{PJ,2,p}$	Total electricity consumed during the period $p$ by the high efficiency equipment introduced in the project categorized as measure 2 [kWh/p]
$EC_{PJ2,i,p}$	Electricity consumed during the period $p$ by the high efficiency equipment $i$ introduced in the project categorized as measure 2 [kWh/p]
$ECA_i$	Capacity of auxiliary electric equipment that is installed due to the implementation of the high efficiency equipment $i$ [kW]
$t_p$	Operating hours of auxiliary electric equipment during the period $p$ [hr/p]

**Measure 3: LED lighting**

$$EC_{PJ,3,p} = \sum_i (EC_{PJ3,i} \times t_{i,p}) \quad (9)$$

Where

$EC_{PJ,3,p}$	Total electricity consumed during the period $p$ by the high efficiency equipment introduced in the project categorized as measure 3 [kWh/p]
$EC_{PJ3,i}$	Rated electricity consumption of the high efficiency equipment $i$ in the project categorized as measure 3 [kW]
$t_{i,p}$	Operating hours of the high efficiency equipment $i$ introduced in the project during the period $p$ categorized as measure 3 [hr/p]

**H. Calculation of emissions reductions**

Emission reduction is calculated by the following equation.

$$ER_p = RE_p - PE_p \quad (10)$$

Where

$ER_p$	Emission reduction during the period $p$ [tCO <sub>2</sub> /p]
$RE_p$	Reference emission during the period $p$ [tCO <sub>2</sub> /p]
$PE_p$	Project emission during the period $p$ [tCO <sub>2</sub> /p]

**I. Data and parameters fixed *ex ante***



The source of each data and parameter fixed *ex ante* is listed as below.

Parameter	Description of data	Source
$\eta_{PJI,i}$	Energy efficiency of the equipment <i>i</i> introduced in the project	Rated/provided by the technology supplier
$\eta_{REF1,i}$	Energy efficiency of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	Default values in the methodology
$ECR_i$	Rated electricity consumption of the high efficiency equipment <i>i</i> introduced in the project	Rated/provided by the technology supplier
$H_i$	Rated heating capacity of the high efficiency equipment <i>i</i> introduced in the project	Rated/provided by the technology supplier
$DC_i$	Unit fuel consumption rate of the reference equipment replaced/ substituted by the equipment <i>i</i> introduced in the project	Rated/provided by the technology supplier
$CH_i$	Rated cooling capacity of the high efficiency equipment <i>i</i> introduced in the project	Rated/provided by the technology supplier
$COP_i$	Efficiency of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	Default values in the methodology
$ECR_{REF3,i}$	Rated electricity consumption of the reference equipment <i>i</i> replaced by the high efficiency equipment <i>i</i> in the project categorized as measure 3	Rated/provided by the technology supplier or checked by the indication on the lighting <i>i</i>
$ECA_i$	Capacity of auxiliary electric equipment that is installed due to the implementation of the high efficiency equipment <i>i</i>	Rated/provided by the technology supplier
$EC_{PJ3,i}$	Rated electricity consumption of the high efficiency equipment <i>i</i> in the project categorized as measure 3	Rated/provided by the technology supplier
$EF_{CO2,ELEC}$	CO <sub>2</sub> emission factor of the electricity consumed  When captive power generation is not available at the project site, then the most recent Vietnamese national grid emission factor [EF <sub>grid</sub> ] available at the time of validation is applied as [EF <sub>CO2,ELEC</sub> ] and fixed for the monitoring period thereafter.	[EF <sub>grid</sub> ] Ministry of Natural Resources and Environment (MONRE), Vietnamese DNA for CDM unless otherwise instructed by

	<p>When captive power generation is available at the project site, then <math>[EF_{CO_2,ELEC}]</math> is conservatively selected as below and fixed for the monitoring period thereafter:</p> $EF_{CO_2,ELEC} = \min (EF_{grid}, EF_{captive})$ $EF_{captive} = 0.8 \text{ tCO}_2/\text{MWh}^*$ <p>*The most recent emission factor available from CDM approved small scale methodology AMS-I.A at the time of validation is applied.</p>	<p>the Joint Committee.</p> <p><math>[EF_{captive}]</math></p> <p>CDM approved small scale methodology: AMS-I.A</p>
$EF_{CO_2}$	CO <sub>2</sub> emission factor of fossil fuel	<p>Country specific data or IPCC default value from “2006 IPCC Guidelines for National Greenhouse Gas Inventories”.</p> <p>Lower limit values of the default net calorific value and CO<sub>2</sub> emission factor are applied.</p>

## History of the document

Version	Date	Contents revised
01.0	14 January 2015	JC3, Annex 4 Initial approval.