

JCM Proposed Methodology Form**Cover sheet of the Proposed Methodology Form**

Form for submitting the proposed methodology

Host Country	Myanmar
Name of the methodology proponents submitting this form	Institute for Global Environmental Strategies
Sectoral scope(s) to which the Proposed Methodology applies	1.Energy industries (renewable – / non-renewable sources)
Title of the proposed methodology, and version number	Power Generation by Waste Heat Recovery in Cement Industry
List of documents to be attached to this form (please check):	<input type="checkbox"/> The attached draft JCM-PDD: <input checked="" type="checkbox"/> Additional information
Date of completion	17/07/2019

History of the proposed methodology

Version	Date	Contents revised
1.0	17/07/2019	First edition

A. Title of the methodology

Power Generation by Waste Heat Recovery in Cement Industry

B. Terms and definitions

Terms	Definitions
Waste heat	Heat generated from cement production facility which would not have been recovered in the absence of the project.
Preheater boiler	Boiler which recovers waste heat from a preheater, which pre-heats raw materials fed into a rotary kiln, to generate steam.
Air Quenching Cooler boiler (AQC boiler)	Boiler which recovers waste heat from an air quenching cooler to generate steam.
Waste Heat Recovery system (WHR system)	Power generation system consisting of a preheater boiler and/or AQC boiler, turbine generator and cooling tower that utilizes waste heat from cement production facility.

C. Summary of the methodology

Items	Summary
<i>GHG emission reduction measures</i>	WHR system generates electricity through waste heat recovered from cement production facility. Electricity generated from the WHR system replaces grid electricity and/or captive use resulting in GHG emission reductions of the connected electricity system.
<i>Calculation of reference emissions</i>	Reference emissions are calculated from net electricity generation by the project which replaces grid electricity and/or captive use where the project is implemented during a given time period.
<i>Calculation of project emissions</i>	Project emissions are not considered as the WHR system does not utilize any fossil fuel as a heat source to generate steam for power generation.

<i>Monitoring parameters</i>	The quantity of the electricity supplied from the WHR system to the cement production facility and the number of days during a monitoring period
------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------

D. Eligibility criteria

This methodology is applicable to projects that satisfy all of the following criteria.

Criterion 1	The project installs WHR system in the cement production facility.
Criterion 2	WHR system utilizes only waste heat and does not utilize fossil fuels as a heat source to generate steam for power generation.
Criterion 3	WHR system has not been introduced to a corresponding cement kiln of the project prior to its implementation.

E. Emission Sources and GHG types

Reference emissions	
Emission sources	GHG types
Grid electricity and/or captive power generation	CO ₂
Project emissions	
Emission sources	GHG types
N/A	N/A

F. Establishment and calculation of reference emissions

F.1. Establishment of reference emissions

Reference emissions are calculated on the basis of net electricity generation by the project that replaces grid and/or captive electricity.

The quantity of electricity consumed by the WHR system except for direct captive use of the electricity generated by itself is subtracted from the quantity of the electricity supplied from the WHR system to the cement production facility to calculate net electricity generation.

In order to ensure conservativeness, the quantity of electricity consumption by the WHR system except for the direct captive use of the electricity generated by itself, is calculated by

using the theoretically maximum load for the capacity of equipment in the above-mentioned WHR system.

F.2. Calculation of reference emissions

$$RE_p = EG_p * EF_{elec}$$

Where,

- RE_p : Reference emissions during a given time period p [tCO₂/p]
 EG_p : The quantity of net electricity generation by the WHR system during a given time period p [MWh/p]
 EF_{elec} : CO₂ emission factor for consumed electricity [tCO₂/MWh]

Determination of EG_p

$$EG_p = EG_{SUP,p} - EC_{AUX,p}$$

- $EG_{SUP,p}$: The quantity of the electricity supplied from the WHR system to the cement production facility during a given time period p [MWh/p]
 $EC_{AUX,p}$: The quantity of electricity consumption by the WHR system except for the direct captive use of the electricity generated by itself during a given time period p [MWh/p]

Determination of $EC_{AUX,p}$

$$EC_{AUX,p} = EC_{CAP} * 24(hours/day) * D_p$$

- EC_{CAP} : The total maximum rated capacity of equipment of the WHR system which consumes electricity except for the capacity of equipment which uses the electricity generated by itself directly [MW]
 D_p : The number of days during a given time period p [day/p]

G. Calculation of project emissions

Project emissions are not assumed in the methodology as the WHR system utilizes only waste heat and does not utilize fossil fuels as heat source to generate steam for power generation, which is prescribed in the eligibility criterion 2.

Therefore, the following formula is used to express the project emissions:

$$PE_p = 0$$

PE_p : Project emissions during a given time period p [tCO₂/p]

H. Calculation of emissions reductions

Emission reductions are calculated as the difference between the reference emissions and project emissions, as follows:

$$ER_p = RE_p - PE_p$$

ER_p : Emission reductions during a given time period p [tCO₂/p]

RE_p : Reference emissions during a given time period p [tCO₂/p]

PE_p : Project emissions during a given time period p [tCO₂/p]

I. Data and parameters fixed *ex ante*

The source of each data and parameter fixed *ex ante* is listed as below.

Parameter	Description of data	Source
EF^{elec}	<p>CO₂ emission factor for consumed electricity.</p> <p>When the electricity supplied from the WHR system displaces only grid electricity or captive electricity, the project participant applies the CO₂ emission factor respectively.</p> <p>When the electricity supplied from the WHR system displaces both grid electricity and captive electricity, the project participant applies the CO₂ emission factor with lower value.</p> <p>[CO₂ emission factor]</p> <p>For grid electricity: The most recent value available from the source stated in this table at the time of validation</p> <p>For captive electricity, it is determined based on the following options:</p> <p>a) <u>Calculated from its power generation</u></p>	<p>[Grid electricity]</p> <p>PDD of the most recently registered CDM project hosted in Myanmar or the latest version of the “Tool to calculate the emission factor for an electricity system” under the CDM at the time of validation.</p> <p>[Captive electricity]</p> <p>For the option a)</p> <p>Specification of the captive power generation system provided by the manufacturer (EF_{elec} [%]).</p> <p>CO₂ emission factor of the fossil fuel type used in the captive power generation system (EF_{fuel} [tCO₂/GJ])</p> <p>For the option b)</p>

	<p><u>efficiency (η_{elec} [%]) obtained from manufacturer's specification</u></p> <p>The power generation efficiency based on lower heating value (LHV) of the captive power generation system from the manufacturer's specification is applied;</p> $EF_{elec} = 3.6 \times \frac{100}{\eta_{elec}} \times EF_{fuel}$ <p><u>b) Calculated from measured data</u></p> <p>The power generation efficiency calculated from monitored data of the amount of fuel input for power generation ($FC_{PJ,p}$) and the amount of electricity generated ($EG_{PJ,p}$) during the monitoring period p is applied. The measurement is conducted with the monitoring equipment to which calibration certificate is issued by an entity accredited under national/international standards;</p> $EF_{elec} = FC_{PJ,p} \times NCV_{fuel} \times EF_{fuel} \times \frac{1}{EG_{PJ,p}}$ <p>Where:</p> <p>NCV_{fuel} : Net calorific value of consumed fuel [GJ/mass or weight]</p> <p>Note:</p> <p>In case the captive electricity generation system meets all of the following conditions, the value in the following table may be applied to EF_{elec} depending on the consumed fuel type.</p> <ul style="list-style-type: none"> • The system is non-renewable generation system 	<p>Generated and supplied electricity by the captive power generation system ($EG_{PJ,p}$ [MWh/p]).</p> <p>Fuel amount consumed by the captive power generation system ($FC_{PJ,p}$ [mass or weight/p]).</p> <p>Net calorific value (NCV_{fuel} [GJ/mass or weight]) and CO₂ emission factor of the fuel (EF_{fuel} [tCO₂/GJ]) in order of preference:</p> <ol style="list-style-type: none"> 1) values provided by the fuel supplier; 2) measurement by the project participants; 3) regional or national default values; 4) IPCC default values provided in table 1.2 and 1.4 of Ch.1 Vol.2 of 2006 IPCC Guidelines on National GHG Inventories. Lower value is applied. <p>[Captive electricity with diesel fuel]</p> <p>CDM approved small scale methodology: AMS-I.A.</p> <p>[Captive electricity with natural gas]</p> <p>2006 IPCC Guidelines on National GHG Inventories for the source of EF of natural gas.</p>
--	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

	<ul style="list-style-type: none"> Electricity generation capacity of the system is less than or equal to 15 MW <table border="1" data-bbox="427 371 979 472"> <thead> <tr> <th>Fuel type</th> <th>Diesel type</th> <th>Natural gas</th> </tr> </thead> <tbody> <tr> <td>EF_{elec}</td> <td>0.8*₁</td> <td>0.46*₂</td> </tr> </tbody> </table> <p>*1 The most recent value at the time of validation is applied.</p> <p>*2 The value is calculated with the equation in the option a) above. The lower value of default effective CO₂ emission factor for natural gas (0.0543tCO₂/GJ), and the most efficient value of default efficiency for off-grid gas turbine systems (42%) are applied.</p>	Fuel type	Diesel type	Natural gas	EF_{elec}	0.8* ₁	0.46* ₂	<p>CDM Methodological tool "Determining the baseline efficiency of thermal or electric energy generation systems version 02.0" for the default efficiency for off-grid power plants.</p>
Fuel type	Diesel type	Natural gas						
EF_{elec}	0.8* ₁	0.46* ₂						
EC_{CAP}	<p>The total maximum rated capacity of equipment of the WHR system which consumes electricity except for the capacity of equipment which use the electricity generated by itself directly</p>	<p>Rated capacity of all installed equipment of the WHR system which consumes electricity except for the capacity of equipment which use the electricity generated by itself directly</p>						