Table 1: Parameters monitored ex post

(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
Monitoring period	Monitoring point No.	Parameters	Description of data	Monitored Values	Units	Monitoring option	Source of data	Measurement methods and procedures	Monitoring frequency	Other comments
2016/4/1- 2016/12/31	1	FC _{PJ1,i,p}	Fossil fuel consumed during the period <i>p</i> by the high efficiency equipment <i>i</i> introduced in the project categorized as measure 1	182,949	L/p	Option C	Monitored data	Fossil fuel consumption is monitored by a volumetric meter subject to maintenance/calibration/replacement in line with manufacturer's or meter suppliers' specifications	Monitored continuously and recorded monthly	
2016/4/1- 2016/12/31	2	EC _{PJ2,i,p}	Electricity consumed during the period <i>p</i> by the high efficiency equipment <i>i</i> introduced in the project categorized as measure 2	136,014	kWh/p	Option C	Monitored data	Electricity consumption is measured by an electricity meter. The meter is calibrated or replaced in line with relevant national/international standards, or manufacturer's specifications.	Monitored continuously and recorded monthly	
2016/4/1- 2016/12/31	3	t _p	Operating hours of auxiliary electric equipment during the period <i>p</i>	6,600	hr/p	Option C	Monitored data	Operating hours are checked against an operation record taken by the project participant	monitored and recorded monthly	Conservative assumption of continuous operation
2016/4/1- 2016/12/31	4	t _{i,p}	Operating hours of the high efficiency equipment <i>i</i> introduced in the project during the period <i>p</i> categorized as measure 3	5,850	hr/p	Option C	Monitored data	Operating hours are checked against an operation schedule prepared by the project participant.	monitored and recorded monthly	

Table 2: Project-specific parameters fixed ex ante

(a)	(b)	(c)	(d)	(e)	(f)
Parameters	Description of data	Estimated Values	Units	Source of data	Other comments
η _{ΡJ1,i}	Energy efficiency of the equipment <i>i</i> introduced in the project	0.93	dimensionless	Rated/provided by the technology supplier	
η _{REF1,i}	Energy efficiency of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	0.90	dimensionless	Default values are applied - New natural gas fired boiler (w/o condenser): 92% - New oil fired boiler: 90% - New coal fired boiler: 85% The latest version of CDM Tool to determine the baseline efficiency of thermal or electric energy generation systems	
ECR _i	Rated electricity consumption of the high efficiency equipment <i>i</i> introduced in the project	19	kW	Rated/provided by the technology supplier	
H _i	Rated heating capacity of the high efficiency equipment <i>i</i> introduced in the project	83	kW	Rated/provided by the technology supplier	
DC,	Unit fuel consumption rate of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	0	L/kWh	Rated/provided by the technology supplier	
CH _i	Rated cooling capacity of the high efficiency equipment <i>i</i> introduced in the project	0	kW	Rated/provided by the technology supplier	
COP _i	Efficiency of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	5.71	dimensionless	Default values are applied Cooling Capacity/unit (USRT) - $x \le 250$ USRT: COP 5.71 - 250 USRT < $x \le 300$ USRT: COP 5.75 - 300 USRT< $x \le 500$ USRT: COP 5.91	
ECR _{REF3,i}	Rated electricity consumption of the reference equipment <i>i</i> replaced by the high efficiency equipment <i>i</i> in the project categorized as measure 3	14	kW	Rated/provided by the technology supplier	
ECA _i	Capacity of auxiliary electric equipment that is installed due to the implementation of the high efficiency equipment <i>i</i>	1	kW	Rated/provided by the technology supplier	
EC _{PJ3,i}	Rated electricity consumption of the high efficiency lighting <i>i</i> in the project categorized as measure 3	4	kW	Rated/provided by the technology supplier	
EF _{CO2,ELEC}	CO_2 emission factor of the electricity consumed When captive power generation is not available at the project site, then the most recent Vietnamese national grid emission factor [EF_{grid}] available at the time of validation is applied as [$EF_{CO2,ELEC}$] and fixed for the monitoring period thereafter. When captive power generation is available at the project site, then [$EF_{CO2,ELEC}$] is conservatively selected as below and fixed for the monitoring period thereafter: $EF_{CO2,ELEC} = \min (EF_{grid}, EF_{captive})$ $EF_{captive} = 0.8 tCO_2/MWh^*$ *The most recent emission factor available from CDM approved small scale methodology AMS-I.A at the time of validation is applied.	0.566	tCO ₂ /MWh	[EFgrid] Ministry of Natural Resources and Environment (MONRE), Vietnamese DNA for CDM unless otherwise instructed by the Joint Committee. [EFcaptive] CDM approved small scale methodology: AMS-I.A	
EF _{CO2}	CO ₂ emission factor of fossil fuel	0.002720	tCO ₂ /L	Country specific data or IPCC default value from "2006 IPCC Guidelines for National Greenhouse Gas Inventories". Lower limit values of the default net calorific value and CO2 emission factor are applied.	

1

Table3: *Ex-post* calculation of CO₂ emission reductions

Monitoring Period	CO ₂ emission reductions	Units
2016/4/1-2016/12/31	155	tCO ₂ /p

Option A	Based on public data which is measured by entities other than the project participants (Data used: publicly recognized data such as
	statistical data and specifications)
Ontion D	Based on the amount of transaction which is measured directly using measuring equipments (Data used: commercial evidence such as
Ориоп в	invoices)
Option C	Based on the actual measurement using measuring equipments (Data used: measured values)

1. C	Calcu	ulations for emission reductions	Fuel type	Value	Units	Parameter
	Em	ission reductions during the period p	N/A	155.7	tCO ₂ /p	ERp
2. 8	elec	cted default values, etc.				
	Effi	ciency of reference boiler		0.90	-	η _{REF1,i}
	Effi	ciency of project boiler		0.93	-	η _{PJ1,i}
	CO	P of reference chiller		5.71	-	COP _i
3. C	alcı	ulations for reference emissions				
	Ref	erence emissions during the period <i>p</i>	N/A	747.5	tCO ₂ /p	REp
		Reference emissions (Fuel consumption)		700.2	tCO ₂ /p	-
		Fossil fuel consumed during the period p by reference equipment (measures 1 and 2)		257,381	L/p	ΣFC _{REF,i,p}
		Fossil fuel consumed during the period p by the reference equipment (measure 1)		189,047	L/p	FC _{REF,1,p}
		Energy efficiency of the high efficiency equipment (measure 1)		0.93	-	η _{PJ1,i}
		Energy efficiency of the reference equipment (measure 1)		0.90	-	η _{REF1,i}
		Fossil fuel consumed during the period p by the high efficiency equipment (measure 1)		182,949	L/p	FC _{PJ1,i,p}
		Fossil fuel consumed during the period p by reference equipment (measure 2)		68,334	L/p	FC _{REF,2,p}
		Rated electricity consumption of the high efficiency equipment (measure 2)	Electricity	19	kW	ECR _i
		Rated heating capacity of the high efficiency equipment (measure 2)		83	kW	H _i
		Unit fuel consumption rate of the reference equipment (measure 2)		0	L/kWh	DC _i
		CO ₂ emission factor of fossil fuel		0.002720	tCO ₂ /L	EF _{CO2}
		Reference emissions (Power consumption)		47.3	tCO ₂ /p	-
		Electricity consumed during the period p by the reference equipment (measures 2 and 3)	Electricity	83,693	kWh/p	ΣEC _{REF,i,p}
		Electricity consumed during the period p by the reference equipment (measure 2)	Electricity	0	kWh/p	EC _{REF,2,p}
		Rated electricity consumption of the high efficiency equipment (measure 2)		19	kW	ECR _i
		Rated cooling capacity of the high efficiency equipment (measure 2)		0	kW	CH _i
		Efficiency of reference cooling equipment (measure 2)		5.71		COP _i
		Electricity consumed during the period p by the high efficiency equipment (measure 2)	Electricity	136,014	kWh/p	EC _{PJ2,i,p}
		Electricity consumed during the period p by the reference equipment (measure 3)	Electricity	83,693	kWh/p	EC _{REF,3,p}
		Rated electricity consumption of the reference equipment (measure 3)	Electricity	14	kW	ECR _{REF3,i}
		Operating hours of the high efficiency equipment during the period p (measure 3)		5,850	hr/p	t _{i,p}
		CO ₂ emission factor of electricity consumed		0.566	tCO ₂ /MWh	EF _{CO2 FLEC}

4. Calcı	Ilations of the project emissions				
Proj	ect emissions during the period of p	N/A	591.9	tCO ₂ /p	PEp
	Project emissions (Fuel consumption)		497.7	tCO ₂ /p	-
	Fossil fuel consumed during the period p by the high efficiency equipment (measure 1)		182,949	L/p	FC _{PJ1,i,p}
	CO ₂ emission factor of fossil fuel		0.00272	tCO ₂ /L	EF _{CO2}
	Project emissions (Power consumption)		94.1	tCO ₂ /p	-
	Total electricity consumed during the period p by the high efficiency equipment (measure 2 and 3)	Electricity	166,431	kWh/p	$\Sigma EC_{PJ,i,p}$
	Total electricity consumed during the period p by the high efficiency equipment (measure 2)	Electricity	140,502	kWh/p	EC _{PJ,2,p}
	Capacity of auxiliary electric equipment		1	kW	ECA _i
	Operating hours of auxiliary electric equipment during the period <i>p</i>		6,600	hr/p	t _p
	Electricity consumed during the period p by the high efficiency equipment (measure 3)	Electricity	25,929	kWh/p	EC _{PJ,3,p}
	Rated electricity consumption of the high efficiency equipment (measure 3)	Electricity	4	kW	EC _{PJ3,i}
	Operating hours of the high efficiency equipment during the period p (measure 3)		5,850	hr/p	t _{i,p}
	CO ₂ emission factor of electricity consumed		0.566	tCO ₂ /MWh	EF _{CO2.ELEC}

Boiler efficiency (new natural gas fired boiler w/o condenser)	0.92	
Boiler efficiency (new oil fired boiler)	0.90	
Boiler efficiency (new coal fired boiler)	0.85	
Chiller COP (x ≤ 250USRT)	5.71	
Chiller COP (250< x ≤300USRT)	5.75	
Chiller COP (300 < x ≤500USRT)	5.91	

Table 1: Parameters monitored ex post

(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
Monitoring period	Monitoring point No.	Parameters	Description of data	Monitored Values	Units	Monitoring option	Source of data	Measurement methods and procedures	Monitoring frequency	Other comments
2016/4/1- 2016/12/31	1	FC _{PJ1,i,p}	Fossil fuel consumed during the period <i>p</i> by the high efficiency equipment <i>i</i> introduced in the project categorized as measure 1	185,031	L/p	Option C	Monitored data	Fossil fuel consumption is monitored by a volumetric meter subject to maintenance/calibration/replacement in line with manufacturer's or meter suppliers' specifications	Monitored continuously and recorded monthly	
2016/4/1- 2016/12/31	2	EC _{PJ2,i,p}	Electricity consumed during the period <i>p</i> by the high efficiency equipment <i>i</i> introduced in the project categorized as measure 2	0	kWh/p	Option C	Monitored data	Electricity consumption is measured by an electricity meter. The meter is calibrated or replaced in line with relevant national/international standards, or manufacturer's specifications.	Monitored continuously and recorded monthly	not applicable to the project
2016/4/1- 2016/12/31	3	t _p	Operating hours of auxiliary electric equipment during the period <i>p</i>	6,600	hr/p	Option C	Monitored data	Operating hours are checked against an operation record taken by the project participant	monitored and recorded monthly	Conservative assumption of continuous operation
2016/4/1- 2016/12/31	4	t _{i,p}	Operating hours of the high efficiency equipment <i>i</i> introduced in the project during the period <i>p</i> categorized as measure 3	0	hr/p	Option C	Monitored data	Operating hours are checked against an operation schedule prepared by the project participant.	monitored and recorded monthly	not applicable to the project

Table 2: Project-specific parameters fixed ex ante

	(a)	(b)	(c)	(d)	(e)	(f)
	Parameters	Description of data	Estimated Values	Units	Source of data	Other comments
	η _{ΡJ1,i}	Energy efficiency of the equipment <i>i</i> introduced in the project	0.93	dimensionless	Rated/provided by the technology supplier	
-	η _{REF1,i}	Energy efficiency of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	0.90	dimensionless	Default values are applied - New natural gas fired boiler (w/o condenser): 92% - New oil fired boiler: 90% - New coal fired boiler: 85% The latest version of CDM Tool to determine the baseline efficiency of thermal or electric energy generation systems	
	ECR _i	Rated electricity consumption of the high efficiency equipment <i>i</i> introduced in the project	0	kW	Rated/provided by the technology supplier	
	H _i	Rated heating capacity of the high efficiency equipment <i>i</i> introduced in the project	0	kW	Rated/provided by the technology supplier	
	DC _i	Unit fuel consumption rate of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	0	L/kWh	Rated/provided by the technology supplier	
	CH _i	Rated cooling capacity of the high efficiency equipment <i>i</i> introduced in the project	0	kW	Rated/provided by the technology supplier	
	COPi	Efficiency of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	5.71	dimensionless	Default values are applied Cooling Capacity/unit (USRT) - $x \le 250$ USRT: COP 5.71 - 250 USRT < $x \le 300$ USRT: COP 5.75 - 300 USRT < $x \le 500$ USRT: COP 5.91	
	ECR _{REF3,i}	Rated electricity consumption of the reference equipment <i>i</i> replaced by the high efficiency equipment <i>i</i> in the project categorized as measure 3	0	kW	Rated/provided by the technology supplier	
	ECA _i	Capacity of auxiliary electric equipment that is installed due to the implementation of the high efficiency equipment <i>i</i>	0	kW	Rated/provided by the technology supplier	
	EC _{PJ3,i}	Rated electricity consumption of the high efficiency lighting <i>i</i> in the project categorized as measure 3	0	kW	Rated/provided by the technology supplier	
	EF _{co2,ELEC}	CO_2 emission factor of the electricity consumed When captive power generation is not available at the project site, then the most recent Vietnamese national grid emission factor [EF_{grid}] available at the time of validation is applied as $[EF_{CO2,ELEC}]$ and fixed for the monitoring period thereafter. When captive power generation is available at the project site, then $[EF_{CO2,ELEC}]$ is conservatively selected as below and fixed for the monitoring period thereafter: $EF_{CO2,ELEC} = \min (EF_{grid}, EF_{captive})$ $EF_{captive} = 0.8 tCO_2/MWh^*$ *The most recent emission factor available from CDM approved small scale methodology AMS-I.A at the time of validation is applied.	0.566	tCO ₂ /MWh	[EFgrid] Ministry of Natural Resources and Environment (MONRE), Vietnamese DNA for CDM unless otherwise instructed by the Joint Committee. [EFcaptive] CDM approved small scale methodology: AMS-I.A	
	EF _{CO2}	CO_2 emission factor of fossil fuel	0.002720	tCO ₂ /L	Country specific data or IPCC default value from "2006 IPCC Guidelines for National Greenhouse Gas Inventories". Lower limit values of the default net calorific value and CO2 emission factor are applied.	

4

Table3: *Ex-post* calculation of CO₂ emission reductions

Monitoring Period	CO ₂ emission reductions	Units
2016/4/1-2016/12/31	16	tCO ₂ /p

[Monitoring option]

Option A	Based on public data which is measured by entities other than the project participants (Data used: publicly recognized data such as statistical data and specifications)
Option B	Based on the amount of transaction which is measured directly using measuring equipments (Data used: commercial evidence such as invoices)
Option C	Based on the actual measurement using measuring equipments (Data used: measured values)

. Ca	alcu	Ilations for emission reductions	Fuel type	Value	Units	Parameter
	Emi	ssion reductions during the period <i>p</i>	N/A	16.8	tCO ₂ /p	ERp
. Se	elec	ted default values, etc.				
	Effic	ciency of reference boiler		0.90	-	η _{REF1,i}
	Effic	ciency of project boiler		0.93	-	η _{PJ1,i}
	COF	of reference chiller		5.71	-	COPi
. Ca	alcu	Ilations for reference emissions				
	Refe	erence emissions during the period p	N/A	520.1	tCO ₂ /p	REp
		Reference emissions (Fuel consumption)		520.1	tCO ₂ /p	-
		Fossil fuel consumed during the period p by reference equipment (measures 1 and 2)		191,199	L/p	$\Sigma FC_{REF,i,p}$
		Fossil fuel consumed during the period p by the reference equipment (measure 1)		191,199	L/p	FC _{REF,1,p}
		Energy efficiency of the high efficiency equipment (measure 1)		0.93	-	η _{PJ1,i}
		Energy efficiency of the reference equipment (measure 1)		0.90	-	η _{REF1,i}
		Fossil fuel consumed during the period p by the high efficiency equipment (measure 1)		185,031	L/p	FC _{PJ1,i,p}
		Fossil fuel consumed during the period p by reference equipment (measure 2)		0	L/p	FC _{REF,2,p}
		Rated electricity consumption of the high efficiency equipment (measure 2)	Electricity	0	kW	ECR_{i}
		Rated heating capacity of the high efficiency equipment (measure 2)		0	kW	H _i
		Unit fuel consumption rate of the reference equipment (measure 2)		0	L/kWh	DCi
		CO ₂ emission factor of fossil fuel		0.002720	tCO ₂ /L	EF _{CO2}
		Reference emissions (Power consumption)		0.0	tCO ₂ /p	-
		Electricity consumed during the period p by the reference equipment (measures 2 and 3)	Electricity	0	kWh/p	$\Sigma EC_{REF,i,p}$
		Electricity consumed during the period p by the reference equipment (measure 2)	Electricity	0	kWh/p	EC _{REF,2,p}
		Rated electricity consumption of the high efficiency equipment (measure 2)		0	kW	ECR _i
		Rated cooling capacity of the high efficiency equipment (measure 2)		0	kW	CH _i
		Efficiency of reference cooling equipment (measure 2)		5.71		COP _i
		 Electricity consumed during the period <i>p</i> by the high efficiency equipment (measure 2) Electricity consumed during the period <i>p</i> by the reference equipment (measure 3) 		0	kWh/p	EC _{PJ2,i,p}
				0	kWh/p	EC _{REF,3,p}
		Rated electricity consumption of the reference equipment (measure 3)	Electricity	0	kW	ECR _{REF3,i}
		Operating hours of the high efficiency equipment during the period p (measure 3)		0	hr/p	t _{i,p}
		CO ₂ emission factor of electricity consumed		0.566	tCO ₂ /MWh	EF _{CO2 ELEC}

4. Calc	ulations of the project emissions				
Pro	ject emissions during the period of <i>p</i>	N/A	503.4	tCO ₂ /p	PEp
	Project emissions (Fuel consumption)		503.4	tCO ₂ /p	-
	Fossil fuel consumed during the period p by the high efficiency equipment (measure 1)		185,031	L/p	FC _{PJ1,i,p}
	CO ₂ emission factor of fossil fuel		0.00272	tCO ₂ /L	EF _{CO2}
	Project emissions (Power consumption)		0.0	tCO ₂ /p	-
	Total electricity consumed during the period p by the high efficiency equipment (measure 2 and 3)	Electricity	0	kWh/p	$\Sigma EC_{PJ,i,p}$
	Total electricity consumed during the period p by the high efficiency equipment (measure 2)	Electricity	0	kWh/p	EC _{PJ,2,p}
	Capacity of auxiliary electric equipment		0	kW	ECA _i
	Operating hours of auxiliary electric equipment during the period <i>p</i>		6,600	hr/p	t _p
	Electricity consumed during the period p by the high efficiency equipment (measure 3)	Electricity	0	kWh/p	$EC_{PJ,3,p}$
	Rated electricity consumption of the high efficiency equipment (measure 3)	Electricity	0	kW	EC _{PJ3,i}
	Operating hours of the high efficiency equipment during the period p (measure 3)		0	hr/p	t _{i,p}
	CO ₂ emission factor of electricity consumed		0.566	tCO ₂ /MWh	EF _{CO2.ELEC}

Boiler efficiency (new natural gas fired boiler w/o condenser)	0.92	
Boiler efficiency (new oil fired boiler)	0.90	
Boiler efficiency (new coal fired boiler)	0.85	
Chiller COP (x ≤ 250USRT)	5.71	
Chiller COP (250< x ≤300USRT)	5.75	
Chiller COP (300 < x ≤500USRT)	5.91	

Table 1: Parameters monitored ex post

(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
Monitoring period	Monitoring point No.	Parameters	Description of data	Monitored Values	Units	Monitoring option	Source of data	Measurement methods and procedures	Monitoring frequency	Other comments
2017/1/1- 2017/5/31	1	FC _{PJ1,i,p}	Fossil fuel consumed during the period <i>p</i> by the high efficiency equipment <i>i</i> introduced in the project categorized as measure 1	116,116	L/p	Option C	Monitored data	Fossil fuel consumption is monitored by a volumetric meter subject to maintenance/calibration/replacement in line with manufacturer's or meter suppliers' specifications	Monitored continuously and recorded monthly	
2017/1/1- 2017/5/31	2	EC _{PJ2,i,p}	Electricity consumed during the period <i>p</i> by the high efficiency equipment <i>i</i> introduced in the project categorized as measure 2	70,974	kWh/p	Option C	Monitored data	Electricity consumption is measured by an electricity meter. The meter is calibrated or replaced in line with relevant national/international standards, or manufacturer's specifications.	Monitored continuously and recorded monthly	
2017/1/1- 2017/5/31	3	t _p	Operating hours of auxiliary electric equipment during the period <i>p</i>	3,624	hr/p	Option C	Monitored data	Operating hours are checked against an operation record taken by the project participant	monitored and recorded monthly	Conservative assumption of continuous operation
2017/1/1- 2017/5/31	4	t _{i,p}	Operating hours of the high efficiency equipment <i>i</i> introduced in the project during the period <i>p</i> categorized as measure 3	3,212	hr/p	Option C	Monitored data	Operating hours are checked against an operation schedule prepared by the project participant.	monitored and recorded monthly	

Table 2: Project-specific parameters fixed ex ante

(a)	(b)	(c)	(d)	(e)	(f)
Parameters	Description of data	Estimated Values	Units	Source of data	Other comments
η _{ΡJ1,i}	Energy efficiency of the equipment <i>i</i> introduced in the project	0.93	dimensionless	Rated/provided by the technology supplier	
η _{REF1,i}	Energy efficiency of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	0.90	dimensionless	Default values are applied - New natural gas fired boiler (w/o condenser): 92% - New oil fired boiler: 90% - New coal fired boiler: 85% The latest version of CDM Tool to determine the baseline efficiency of thermal or electric energy generation systems	
ECR _i	Rated electricity consumption of the high efficiency equipment <i>i</i> introduced in the project	19	kW	Rated/provided by the technology supplier	
H _i	Rated heating capacity of the high efficiency equipment <i>i</i> introduced in the project	83	kW	Rated/provided by the technology supplier	
DC _i	Unit fuel consumption rate of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	0	L/kWh	Rated/provided by the technology supplier	
CH _i	Rated cooling capacity of the high efficiency equipment <i>i</i> introduced in the project	0	kW	Rated/provided by the technology supplier	
COPi	Efficiency of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	5.71	dimensionless	Default values are applied Cooling Capacity/unit (USRT) - x ≤ 250 USRT: COP 5.71 - 250 USRT < x ≤ 300 USRT: COP 5.75 - 300 USRT <x 5.91<="" 500="" cop="" td="" usrt:="" ≤=""><td></td></x>	
ECR _{REF3,i}	Rated electricity consumption of the reference equipment <i>i</i> replaced by the high efficiency equipment <i>i</i> in the project categorized as measure 3	14	kW	Rated/provided by the technology supplier	
ECA _i	Capacity of auxiliary electric equipment that is installed due to the implementation of the high efficiency equipment <i>i</i>	1	kW	Rated/provided by the technology supplier	
EC _{PJ3,i}	Rated electricity consumption of the high efficiency lighting <i>i</i> in the project categorized as measure 3	4	kW	Rated/provided by the technology supplier	
EF _{CO2,ELEC}	CO ₂ emission factor of the electricity consumed When captive power generation is not available at the project site, then the most recent Vietnamese national grid emission factor [EF_{grid}] available at the time of validation is applied as [$EF_{CO2,ELEC}$] and fixed for the monitoring period thereafter. When captive power generation is available at the project site, then [$EF_{CO2,ELEC}$] is conservatively selected as below and fixed for the monitoring period thereafter: $EF_{CO2,ELEC} = min (EF_{grid}, EF_{captive})$ $EF_{captive} = 0.8 tCO_2/MWh^*$ *The most recent emission factor available from CDM approved small scale methodology AMS-I.A at the time of validation is applied.	0.566	tCO ₂ /MWh	[EFgrid] Ministry of Natural Resources and Environment (MONRE), Vietnamese DNA for CDM unless otherwise instructed by the Joint Committee. [EFcaptive] CDM approved small scale methodology: AMS-I.A	
EF _{CO2}	CO ₂ emission factor of fossil fuel	0.002720	tCO ₂ /L	Country specific data or IPCC default value from "2006 IPCC Guidelines for National Greenhouse Gas Inventories". Lower limit values of the default net calorific value and CO2 emission factor are applied.	

1

Table3: *Ex-post* calculation of CO₂ emission reductions

Monitoring Period	CO ₂ emission reductions	Units
2017/1/1-2017/5/31	83	tCO ₂ /p

Option A	Based on public data which is measured by entities other than the project participants (Data used: publicly recognized data such as statistical data and specifications)
Option B	Based on the amount of transaction which is measured directly using measuring equipments (Data used: commercial evidence such as invoices)
Option C	Based on the actual measurement using measuring equipments (Data used: measured values)

1. (Calc	ulations for emission reductions	Fuel type	Value	Units	Parameter
	Em	ission reductions during the period <i>p</i>	N/A	83.9	tCO ₂ /p	ER _p
2. \$	Selec	cted default values, etc.				
	Effi	ciency of reference boiler		0.90	-	η _{REF1,i}
	Effi	ciency of project boiler		0.93	-	η _{PJ1,i}
	CO	P of reference chiller		5.71	-	COPi
3. (Calc	ulations for reference emissions				
	Ref	erence emissions during the period <i>p</i>	N/A	449.4	tCO ₂ /p	REp
		Reference emissions (Fuel consumption)		423.4	tCO ₂ /p	-
		Fossil fuel consumed during the period p by reference equipment (measures 1 and 2)		155,644	L/p	ΣFC _{REF,i,p}
		Fossil fuel consumed during the period p by the reference equipment (measure 1)		119,987	L/p	FC _{REF,1,p}
		Energy efficiency of the high efficiency equipment (measure 1)		0.93	-	η _{PJ1,i}
		Energy efficiency of the reference equipment (measure 1)		0.90	-	η _{REF1,i}
		Fossil fuel consumed during the period p by the high efficiency equipment (measure 1)		116,116	L/p	FC _{PJ1,i,p}
		Fossil fuel consumed during the period p by reference equipment (measure 2)		35,658	L/p	$FC_{REF,2,p}$
		Rated electricity consumption of the high efficiency equipment (measure 2)	Electricity	19	kW	ECR _i
		Rated heating capacity of the high efficiency equipment (measure 2)		83	kW	H _i
		Unit fuel consumption rate of the reference equipment (measure 2)		0	L/kWh	DCi
		CO ₂ emission factor of fossil fuel		0.002720	tCO ₂ /L	EF _{CO2}
		Reference emissions (Power consumption)		26.0	tCO ₂ /p	-
		Electricity consumed during the period p by the reference equipment (measures 2 and 3)	Electricity	45,955	kWh/p	$\Sigma EC_{REF,i,p}$
		Electricity consumed during the period p by the reference equipment (measure 2)	Electricity	0	kWh/p	EC _{REF,2,p}
		Rated electricity consumption of the high efficiency equipment (measure 2)		19	kW	ECR _i
		Rated cooling capacity of the high efficiency equipment (measure 2)		0	kW	CH _i
		Efficiency of reference cooling equipment (measure 2)		5.71		COP _i
		Electricity consumed during the period p by the high efficiency equipment (measure 2)	Electricity	70,974	kWh/p	EC _{PJ2,i,p}
		Electricity consumed during the period p by the reference equipment (measure 3)	Electricity	45,955	kWh/p	EC _{REF,3,p}
		Rated electricity consumption of the reference equipment (measure 3)	Electricity	14	kW	ECR _{REF3,i}
		Operating hours of the high efficiency equipment during the period p (measure 3)		3,212	hr/p	t _{i,p}
		CO ₂ emission factor of electricity consumed		0.566	tCO ₂ /MWh	EFCORELEC

4. Calc	ulations of the project emissions				
Pro	ject emissions during the period of <i>p</i>	N/A	365.5	tCO ₂ /p	PEp
	Project emissions (Fuel consumption)		315.9	tCO ₂ /p	-
	Fossil fuel consumed during the period p by the high efficiency equipment (measure 1)		116,116	L/p	FC _{PJ1,i,p}
	CO ₂ emission factor of fossil fuel		0.00272	tCO ₂ /L	EF _{CO2}
	Project emissions (Power consumption)		49.6	tCO ₂ /p	-
	Total electricity consumed during the period p by the high efficiency equipment (measure 2 and 3)	Electricity	87,676	kWh/p	$\Sigma EC_{PJ,i,p}$
	Total electricity consumed during the period p by the high efficiency equipment (measure 2)	Electricity	73,439	kWh/p	EC _{PJ,2,p}
	Capacity of auxiliary electric equipment		1	kW	ECA _i
	Operating hours of auxiliary electric equipment during the period <i>p</i>		3,624	hr/p	t _p
	Electricity consumed during the period p by the high efficiency equipment (measure 3)	Electricity	14,237	kWh/p	EC _{PJ,3,p}
	Rated electricity consumption of the high efficiency equipment (measure 3)	Electricity	4	kW	EC _{PJ3,i}
	Operating hours of the high efficiency equipment during the period p (measure 3)		3,212	hr/p	t _{i,p}
	CO ₂ emission factor of electricity consumed		0.566	tCO ₂ /MWh	EF _{CO2.ELEC}

Boiler efficiency (new natural gas fired boiler w/o condenser)	0.92	
Boiler efficiency (new oil fired boiler)	0.90	
Boiler efficiency (new coal fired boiler)	0.85	
Chiller COP (x ≤ 250USRT)	5.71	
Chiller COP (250< x ≤300USRT)	5.75	
Chiller COP (300 < x ≤500USRT)	5.91	

Table 1: Parameters monitored ex post

(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
Monitoring period	Monitoring point No.	Parameters	Description of data	Monitored Values	Units	Monitoring option	Source of data	Measurement methods and procedures	Monitoring frequency	Other comments
2017/1/1- 2017/5/31	1	FC _{PJ1,i,p}	Fossil fuel consumed during the period <i>p</i> by the high efficiency equipment <i>i</i> introduced in the project categorized as measure 1	79,308	L/p	Option C	Monitored data	Fossil fuel consumption is monitored by a volumetric meter subject to maintenance/calibration/replacement in line with manufacturer's or meter suppliers' specifications	Monitored continuously and recorded monthly	
2017/1/1- 2017/5/31	2	EC _{PJ2,i,p}	Electricity consumed during the period <i>p</i> by the high efficiency equipment <i>i</i> introduced in the project categorized as measure 2	0	kWh/p	Option C	Monitored data	Electricity consumption is measured by an electricity meter. The meter is calibrated or replaced in line with relevant national/international standards, or manufacturer's specifications.	Monitored continuously and recorded monthly	not applicable to the project
2017/1/1- 2017/5/31	3	t _p	Operating hours of auxiliary electric equipment during the period <i>p</i>	3,624	hr/p	Option C	Monitored data	Operating hours are checked against an operation record taken by the project participant	monitored and recorded monthly	Conservative assumption of continuous operation
2017/1/1- 2017/5/31	4	t _{i,p}	Operating hours of the high efficiency equipment <i>i</i> introduced in the project during the period <i>p</i> categorized as measure 3	0	hr/p	Option C	Monitored data	Operating hours are checked against an operation schedule prepared by the project participant.	monitored and recorded monthly	not applicable to the project

Table 2: Project-specific parameters fixed ex ante

(a)	(b)	(c)	(d)	(e)	(f)
Parameters	Description of data	Estimated Values	Units	Source of data	Other comments
η _{ΡJ1,i}	Energy efficiency of the equipment <i>i</i> introduced in the project	0.93	dimensionless	Rated/provided by the technology supplier	
η _{REF1,i}	Energy efficiency of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	0.90	dimensionless	Default values are applied - New natural gas fired boiler (w/o condenser): 92% - New oil fired boiler: 90% - New coal fired boiler: 85% The latest version of CDM Tool to determine the baseline efficiency of thermal or electric energy generation systems	
ECR _i	Rated electricity consumption of the high efficiency equipment <i>i</i> introduced in the project	0	kW	Rated/provided by the technology supplier	
H _i	Rated heating capacity of the high efficiency equipment <i>i</i> introduced in the project	0	kW	Rated/provided by the technology supplier	
DC _i	Unit fuel consumption rate of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	0	L/kWh	Rated/provided by the technology supplier	
CH _i	Rated cooling capacity of the high efficiency equipment <i>i</i> introduced in the project	0	kW	Rated/provided by the technology supplier	
COP _i	Efficiency of the reference equipment replaced/substituted by the equipment <i>i</i> introduced in the project	ficiency of the reference equipment blaced/substituted by the equipment <i>i</i> 5.71 dime roduced in the project		Default values are applied Cooling Capacity/unit (USRT) - $x \le 250$ USRT: COP 5.71 - 250 USRT < $x \le 300$ USRT: COP 5.75 - 300 USRT< $x \le 500$ USRT: COP 5.91	
ECR _{REF3,i}	Rated electricity consumption of the reference equipment <i>i</i> replaced by the high efficiency equipment <i>i</i> in the project categorized as measure 3	0	kW	Rated/provided by the technology supplier	
ECA _i	Capacity of auxiliary electric equipment that is installed due to the implementation of the high efficiency equipment <i>i</i>	0	ĸW	Rated/provided by the technology supplier	
EC _{PJ3,i}	Rated electricity consumption of the high efficiency lighting <i>i</i> in the project categorized as measure 3	0	kW	Rated/provided by the technology supplier	
EF _{C02,ELEC}	CO_2 emission factor of the electricity consumed When captive power generation is not available at the project site, then the most recent Vietnamese national grid emission factor [EF_{grid}] available at the time of validation is applied as [$EF_{CO2,ELEC}$] and fixed for the monitoring period thereafter. When captive power generation is available at the project site, then [$EF_{CO2,ELEC}$] is conservatively selected as below and fixed for the monitoring period thereafter: $EF_{CO2,ELEC} = min (EF_{grid}, EF_{captive})$ $EF_{captive} = 0.8 tCO_2/MWh^*$ *The most recent emission factor available from CDM approved small scale methodology AMS-I.A at the time of validation is applied.	0.566	tCO ₂ /MWh	[EFgrid] Ministry of Natural Resources and Environment (MONRE), Vietnamese DNA for CDM unless otherwise instructed by the Joint Committee. [EFcaptive] CDM approved small scale methodology: AMS-I.A	
EF _{CO2}	CO ₂ emission factor of fossil fuel	0.002720	tCO ₂ /L	Country specific data or IPCC default value from "2006 IPCC Guidelines for National Greenhouse Gas Inventories". Lower limit values of the default net calorific value and CO2 emission factor are applied.	

4

Table3: *Ex-post* calculation of CO₂ emission reductions

Monitoring Period	CO ₂ emission reductions	Units
2017/1/1-2017/5/31	7	tCO ₂ /p

Option A	Based on public data which is measured by entities other than the project participants (Data used: publicly recognized data such as statistical data and specifications)		
Option B	Based on the amount of transaction which is measured directly using measuring equipments (Data used: commercial evidence such as invoices)		
Option C	Based on the actual measurement using measuring equipments (Data used: measured values)		

2

. Calculations for emission reductions		Fuel type	Value	Units	Parameter	
Emission reductions during the period p			N/A	7.2	tCO ₂ /p	ERp
. Sel	ecte	ed default values, etc.				
E	fficie	ency of reference boiler		0.90	-	η _{REF1,i}
E	fficie	ency of project boiler		0.93	-	η _{PJ1,i}
C	OP	of reference chiller		5.71	-	COP _i
. Ca	Icula	ations for reference emissions				
R	efer	ence emissions during the period <i>p</i>	N/A	222.9	tCO ₂ /p	REp
	R	eference emissions (Fuel consumption)		222.9	tCO ₂ /p	-
		Fossil fuel consumed during the period p by reference equipment (measures 1 and 2)		81,952	L/p	ΣFC _{REF,i,p}
		Fossil fuel consumed during the period <i>p</i> by the reference equipment (measure 1)		81,952	L/p	FC _{REF,1,p}
		Energy efficiency of the high efficiency equipment (measure 1)		0.93	-	η _{PJ1,i}
		Energy efficiency of the reference equipment (measure 1)		0.90	-	η _{REF1,i}
		Fossil fuel consumed during the period p by the high efficiency equipment (measure 1)		79,308	L/p	FC _{PJ1,i,p}
		Fossil fuel consumed during the period p by reference equipment (measure 2)		0	L/p	FC _{REF,2,p}
		Rated electricity consumption of the high efficiency equipment (measure 2)	Electricity	0	kW	ECR _i
		Rated heating capacity of the high efficiency equipment (measure 2)		0	kW	H _i
		Unit fuel consumption rate of the reference equipment (measure 2)		0	L/kWh	DCi
		CO ₂ emission factor of fossil fuel		0.002720	tCO ₂ /L	EF _{CO2}
	R	eference emissions (Power consumption)		0.0	tCO ₂ /p	-
		Electricity consumed during the period p by the reference equipment (measures 2 and 3)	Electricity	0	kWh/p	ΣEC _{REF,i,p}
		Electricity consumed during the period p by the reference equipment (measure 2)	Electricity	0	kWh/p	EC _{REF,2,p}
		Rated electricity consumption of the high efficiency equipment (measure 2)		0	kW	ECR _i
		Rated cooling capacity of the high efficiency equipment (measure 2)		0	kW	CHi
		Efficiency of reference cooling equipment (measure 2)		5.71		COP _i
		Electricity consumed during the period p by the high efficiency equipment (measure 2)	Electricity	0	kWh/p	EC _{PJ2,i,p}
		Electricity consumed during the period p by the reference equipment (measure 3)	Electricity	0	kWh/p	EC _{REF,3,p}
		Rated electricity consumption of the reference equipment (measure 3)	Electricity	0	kW	ECR _{REF3,i}
		Operating hours of the high efficiency equipment during the period p (measure 3)		0	hr/p	t _{i,p}
		CO ₂ emission factor of electricity consumed		0.566	tCO ₂ /MWh	EF _{CO2,ELEC}

4. Calc	ulations of the project emissions				
Pro	pject emissions during the period of <i>p</i>	N/A	215.8	tCO ₂ /p	PEp
	Project emissions (Fuel consumption)		215.8	tCO ₂ /p	-
	Fossil fuel consumed during the period p by the high efficiency equipment (measure 1)		79,308	L/p	FC _{PJ1,i,p}
	CO ₂ emission factor of fossil fuel		0.00272	tCO ₂ /L	EF _{CO2}
	Project emissions (Power consumption)		0.0	tCO ₂ /p	-
	Total electricity consumed during the period p by the high efficiency equipment (measure 2 and 3)	Electricity	0	kWh/p	$\Sigma EC_{PJ,i,p}$
	Total electricity consumed during the period p by the high efficiency equipment (measure 2)	Electricity	0	kWh/p	$EC_{PJ,2,p}$
	Capacity of auxiliary electric equipment		0	kW	ECA _i
	Operating hours of auxiliary electric equipment during the period <i>p</i>		3,624	hr/p	t _p
	Electricity consumed during the period p by the high efficiency equipment (measure 3)	Electricity	0	kWh/p	$EC_{PJ,3,p}$
	Rated electricity consumption of the high efficiency equipment (measure 3)	Electricity	0	kW	EC _{PJ3,i}
	Operating hours of the high efficiency equipment during the period p (measure 3)		0	hr/p	t _{i,p}
	CO ₂ emission factor of electricity consumed		0.566	tCO ₂ /MWh	EF _{CO2,FLEC}

Boiler efficiency (new natural gas fired boiler w/o condenser)	0.92	
Boiler efficiency (new oil fired boiler)	0.90	
Boiler efficiency (new coal fired boiler)	0.85	
Chiller COP (x ≤ 250USRT)	5.71	
Chiller COP (250< x ≤300USRT)	5.75	
Chiller COP (300 < x ≤500USRT)	5.91	