

**Monitoring Report Sheet (Input Sheet) [For Verification]**

**Table 1: Parameters monitored ex post**

(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
Monitoring period	Monitoring point No.	Parameters	Description of data	Monitored Values	Units	Monitoring option	Source of data	Measurement methods and procedures	Monitoring frequency	Other comments
20/9/2015 - 31/12/2015	1	PH <sub>p</sub>	Net heat quantity supplied by the project HOB during the period p.	1,183	GJ/p	Option C	Logged data of net heat quantity supplied by the project HOB	Measurement methods which are using a heatmeter meet the industrial standards (host country or international standard). Monitoring data is the amount of heat supplied from the project HOB. This monitoring data is recorded in the data logger that is built into the heat meter. Electric data recorded on the data logger is input to the spreadsheet properly. In these monitoring activities, QA/QC be implemented. - In the case that heatmeter with verification is used, the verification validity for the heatmeter does not expire till the last date of the monitoring period. - If the heatmeter with the verification is not required in the industrial standard, uncertainty of the calibration data of the monitoring equipment meet the following conditions; - It is within accepted level of the verification. - It is within the accuracy level of industry standard requires. Required calibration frequency is the frequency which can be confirmed to be within the accuracy level of the requirement of industrial standard.	Measuring frequency: Continuously Recording frequency: Hourly	Trouble shooting procedure of missing data; Completed by the hourly minimum value (excluding abnormal value) of available recorded data during the monitoring period.
20/9/2015 - 31/12/2015	2	HMP <sub>p</sub>	Total hours of the project HOB operation during the period p	4,944	hours/p	Option C	Identified by monitoring period	Total time from the start time of monitoring to the end time of monitoring	---	---

**Table 2: Project-specific parameters fixed ex ante**

(a)	(b)	(c)	(d)	(e)	(f)
Parameters	Description of data	Estimated Values	Units	Source of data	Other comments
RPC <sub>PJ,HOB</sub>	Rated power consumption of the project HOB	1	kW	Catalog value provided by the manufacturer of the project HOB	
EF <sub>CO2,grid</sub>	CO <sub>2</sub> emission factor of the grid electricity consumed by the project HOB	1.1030	tCO <sub>2</sub> /MWh	The most recent value available at the time of validation is applied and fixed for the monitoring period thereafter. The data is sourced from CDM Mongolia unless otherwise instructed by the Joint Committee.	

**Table3: Ex-post calculation of CO<sub>2</sub> emission reductions**

Monitoring Period	CO <sub>2</sub> emission reductions	Units
20/9/2015 - 31/12/2015	18	tCO <sub>2</sub> /p

**[Monitoring option]**

Option A	Based on public data which is measured by entities other than the project participants (Data used: publicly recognized data such as statistical data and specifications)
Option B	Based on the amount of transaction which is measured directly using measuring equipments (Data used: commercial evidence such as invoices)
Option C	Based on the actual measurement using measuring equipments (Data used: measured values)

**Monitoring Report Sheet (Calculation Process Sheet) [For Verification]**

1. Calculations for emission reductions	Fuel type	Value	Units	Parameter
Emission reductions during the period $p$	N/A	19	tCO <sub>2</sub> /p	ER <sub>p</sub>
<b>2. Selected default values, etc.</b>				
CO <sub>2</sub> emission factor of coal	Coal	0.0909	tCO <sub>2</sub> /GJ	EF <sub>CO<sub>2</sub>, coal</sub>
Boiler efficiency of the reference HOB	N/A	0.533	-	η <sub>RE,HOB</sub>
Boiler efficiency of the project HOB	N/A	0.610	-	η <sub>PJ,HOB</sub>
<b>3. Calculations for reference emissions</b>				
Reference emissions during the period $p$	N/A	202	tCO <sub>2</sub> /p	RE <sub>p</sub>
Reference Emissions	N/A	202	tCO <sub>2</sub> /p	
Net heat quantity supplied by the project HOB	N/A	1,183	GJ/p	PH <sub>p</sub>
Boiler efficiency of the reference HOB	N/A	0.533	-	η <sub>RE,HOB</sub>
CO <sub>2</sub> emission factor of coal	Coal	0.0909	tCO <sub>2</sub> /GJ	EF <sub>CO<sub>2</sub>, coal</sub>
<b>4. Calculations of the project emissions</b>				
Project emissions during the period $p$	N/A	183	tCO <sub>2</sub> /p	PE <sub>p</sub>
Project emissions (Fossil fuel consumption)	N/A	176	tCO <sub>2</sub> /p	
Net heat quantity supplied by the project HOB	N/A	1,183	GJ/p	PH <sub>p</sub>
Boiler efficiency of the project HOB	N/A	0.610	-	η <sub>PJ,HOB</sub>
CO <sub>2</sub> emission factor of coal	Coal	0.0909	tCO <sub>2</sub> /GJ	EF <sub>CO<sub>2</sub>, coal</sub>
Project emissions (Electricity consumption)	N/A	7	tCO <sub>2</sub> /p	
Electricity consumption of the project HOB	Electricity	6	MWh/p	EC <sub>p</sub>
Total hours of the project HOB operation	N/A	4,944	h/p	HMP <sub>p</sub>
Rated power consumption of the project HOB	N/A	1	kW	RPC <sub>PJ,HOB</sub>
CO <sub>2</sub> emission factor of the grid	Electricity	1.1030	tCO <sub>2</sub> /MWh	EF <sub>CO<sub>2</sub>, grid</sub>

## [List of Default Values]

CO <sub>2</sub> Emission Factor of Coal used in HOBs	EF <sub>CO<sub>2</sub>, coal</sub>	unit
Default emission factor applied to Lignite in fuel according to "2006 IPCC Guidelines for National Greenhouse Gas Inventory"	0.0909	tCO <sub>2</sub> /GJ

Boiler Efficiency of coal-fired HOB in Mongolia	η	unit
Boiler Efficiency of Reference the HOB	0.533	-
Boiler Efficiency of the Project HOB	0.610	-

**Monitoring Report Sheet (Input Sheet) [For Verification]**

**Table 1: Parameters monitored ex post**

(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
Monitoring period	Monitoring point No.	Parameters	Description of data	Monitored Values	Units	Monitoring option	Source of data	Measurement methods and procedures	Monitoring frequency	Other comments
1/1/2016 - 15/5/2016	1	PH <sub>p</sub>	Net heat quantity supplied by the project HOB during the period p.	1,929	GJ/p	Option C	Logged data of net heat quantity supplied by the project HOB	Measurement methods which are using a heatmeter meet the industrial standards (host country or international standard). Monitoring data is the amount of heat supplied from the project HOB. This monitoring data is recorded in the data logger that is built into the heat meter. Electric data recorded on the data logger is input to the spreadsheet properly. In these monitoring activities, QA/QC be implemented. - In the case that heatmeter with verification is used, the verification validity for the heatmeter does not expire till the last date of the monitoring period. - If the heatmeter with the verification is not required in the industrial standard, uncertainty of the calibration data of the monitoring equipment meet the following conditions; - It is within accepted level of the verification. - It is within the accuracy level of industry standard requires. Required calibration frequency is the frequency which can be confirmed to be within the accuracy level of the requirement of industrial standard.	Measuring frequency: Continuously Recording frequency: Hourly	Trouble shooting procedure of missing data; Completed by the hourly minimum value (excluding abnormal value) of available recorded data during the monitoring period.
1/1/2016 - 15/5/2016	2	HMP <sub>p</sub>	Total hours of the project HOB operation during the period p	6,528	hours/p	Option C	Identified by monitoring period	Total time from the start time of monitoring to the end time of monitoring	---	---

**Table 2: Project-specific parameters fixed ex ante**

(a)	(b)	(c)	(d)	(e)	(f)
Parameters	Description of data	Estimated Values	Units	Source of data	Other comments
RPC <sub>PJ,HOB</sub>	Rated power consumption of the project HOB	1	kW	Catalog value provided by the manufacturer of the project HOB	
EF <sub>CO2,grid</sub>	CO <sub>2</sub> emission factor of the grid electricity consumed by the project HOB	1.1030	tCO <sub>2</sub> /MWh	The most recent value available at the time of validation is applied and fixed for the monitoring period thereafter. The data is sourced from CDM Mongolia unless otherwise instructed by the Joint Committee.	

**Table3: Ex-post calculation of CO<sub>2</sub> emission reductions**

Monitoring Period	CO <sub>2</sub> emission reductions	Units
1/1/2016 - 15/5/2016	32	tCO <sub>2</sub> /p

**[Monitoring option]**

Option A	Based on public data which is measured by entities other than the project participants (Data used: publicly recognized data such as statistical data and specifications)
Option B	Based on the amount of transaction which is measured directly using measuring equipments (Data used: commercial evidence such as invoices)
Option C	Based on the actual measurement using measuring equipments (Data used: measured values)

**Monitoring Report Sheet (Calculation Process Sheet) [For Verification]**

1. Calculations for emission reductions	Fuel type	Value	Units	Parameter
Emission reductions during the period $p$	N/A	33	tCO <sub>2</sub> /p	ER <sub>p</sub>
<b>2. Selected default values, etc.</b>				
CO <sub>2</sub> emission factor of coal	Coal	0.0909	tCO <sub>2</sub> /GJ	EF <sub>CO<sub>2</sub>, coal</sub>
Boiler efficiency of the reference HOB	N/A	0.533	-	η <sub>RE,HOB</sub>
Boiler efficiency of the project HOB	N/A	0.610	-	η <sub>PJ,HOB</sub>
<b>3. Calculations for reference emissions</b>				
Reference emissions during the period $p$	N/A	329	tCO <sub>2</sub> /p	RE <sub>p</sub>
Reference Emissions	N/A	329	tCO <sub>2</sub> /p	
Net heat quantity supplied by the project HOB	N/A	1,929	GJ/p	PH <sub>p</sub>
Boiler efficiency of the reference HOB	N/A	0.533	-	η <sub>RE,HOB</sub>
CO <sub>2</sub> emission factor of coal	Coal	0.0909	tCO <sub>2</sub> /GJ	EF <sub>CO<sub>2</sub>, coal</sub>
<b>4. Calculations of the project emissions</b>				
Project emissions during the period $p$	N/A	296	tCO <sub>2</sub> /p	PE <sub>p</sub>
Project emissions (Fossil fuel consumption)	N/A	287	tCO <sub>2</sub> /p	
Net heat quantity supplied by the project HOB	N/A	1,929	GJ/p	PH <sub>p</sub>
Boiler efficiency of the project HOB	N/A	0.610	-	η <sub>PJ,HOB</sub>
CO <sub>2</sub> emission factor of coal	Coal	0.0909	tCO <sub>2</sub> /GJ	EF <sub>CO<sub>2</sub>, coal</sub>
Project emissions (Electricity consumption)	N/A	9	tCO <sub>2</sub> /p	
Electricity consumption of the project HOB	Electricity	8	MWh/p	EC <sub>p</sub>
Total hours of the project HOB operation	N/A	6,528	h/p	HMP <sub>p</sub>
Rated power consumption of the project HOB	N/A	1	kW	RPC <sub>PJ,HOB</sub>
CO <sub>2</sub> emission factor of the grid	Electricity	1.1030	tCO <sub>2</sub> /MWh	EF <sub>CO<sub>2</sub>, grid</sub>

## [List of Default Values]

CO <sub>2</sub> Emission Factor of Coal used in HOBs	EF <sub>CO<sub>2</sub>, coal</sub>	unit
Default emission factor applied to Lignite in fuel according to "2006 IPCC Guidelines for National Greenhouse Gas Inventory"	0.0909	tCO <sub>2</sub> /GJ

Boiler Efficiency of coal-fired HOB in Mongolia	η	unit
Boiler Efficiency of Reference the HOB	0.533	-
Boiler Efficiency of the Project HOB	0.610	-