

JCM Proposed Methodology Form

Cover sheet of the Proposed Methodology Form

Form for submitting the proposed methodology

Host Country	Vietnam
Name of the methodology proponents submitting this form	NTT DATA INSTITUTE OF MANAGEMENT CONSULTING, INC.
Sectoral scope(s) to which the Proposed Methodology applies	3. Energy demand
Title of the proposed methodology, and version number	Introduction of air conditioning system equipped with inverters, Version 01.0
List of documents to be attached to this form (please check):	<input type="checkbox"/> The attached draft JCM-PDD: <input checked="" type="checkbox"/> Additional information
Date of completion	12/08/2016

History of the proposed methodology

Version	Date	Contents revised
01.0	12/08/2016	First edition

A. Title of the methodology

Introduction of air conditioning system equipped with inverters, Version 01.0

B. Terms and definitions

Terms	Definitions
Air-conditioning system with inverters	Air-conditioning system with inverters is a type of air conditioning system which contains inverter, an apparatus to control the speed of the compressor motor in line with different load demand.
Coefficient of Performance (COP)	<p>Coefficient of Performance (COP) is the cooling capacity per rated electricity consumption of the air conditioning system.</p> <p>The values of cooling capacity and rated electricity consumption are defined under specific temperature stated in ISO5151:2010.</p> <p>In this methodology, a COP value of project air conditioning system is set based on calculation by the value of its cooling capacity divided by the electricity consumption of the outdoor unit according to data by manufacturer.</p>

C. Summary of the methodology

Items	Summary
GHG emission reduction measures	This methodology applies to the project that aims for saving energy by introducing air-conditioning system with inverter for cooling in Vietnam.
Calculation of reference emissions	GHG emissions associated with electricity consumption of reference air conditioning system are calculated based on the monitored electricity consumption of project air conditioning system, the ratio of COPs of reference/project air conditioning

	system, and the CO ₂ emission factor of the electricity consumed by project air conditioning system.
Calculation of project emissions	GHG emissions associated with electricity consumption of project air conditioning system are calculated based on the monitored electricity consumption of project air conditioning system and the CO ₂ emission factor of the electricity consumed by project air conditioning system.
Monitoring parameters	<ul style="list-style-type: none"> ● Electricity consumption of outdoor unit of project air conditioning system ● Total electricity consumption of indoor units of project air conditioning system

D. Eligibility criteria

This methodology is applicable to projects that satisfy all of the following criteria.

Criterion 1	Air-conditioning system with inverter is newly installed or installed to replace existing non-inverter air conditioning system.												
Criterion 2	Cooling capacity of project air conditioning system is more than or equal to 14kW.												
Criterion 3	<p>COP of project air-conditioning system has a COP value higher than that of the value indicated in the table below.</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th colspan="2" style="text-align: center;">COP for Reference Air Conditioning System ($COP_{RE,i}$)</th> </tr> <tr> <th style="text-align: center;">Cooling Capacity [kW]</th> <th style="text-align: center;">Reference COP</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">$14 \leq x < 28$</td> <td style="text-align: center;">2.97</td> </tr> <tr> <td style="text-align: center;">$28 \leq x < 42$</td> <td style="text-align: center;">2.94</td> </tr> <tr> <td style="text-align: center;">$42 \leq x < 56$</td> <td style="text-align: center;">2.91</td> </tr> <tr> <td style="text-align: center;">$56 \leq x$</td> <td style="text-align: center;">2.56</td> </tr> </tbody> </table>	COP for Reference Air Conditioning System ($COP_{RE,i}$)		Cooling Capacity [kW]	Reference COP	$14 \leq x < 28$	2.97	$28 \leq x < 42$	2.94	$42 \leq x < 56$	2.91	$56 \leq x$	2.56
COP for Reference Air Conditioning System ($COP_{RE,i}$)													
Cooling Capacity [kW]	Reference COP												
$14 \leq x < 28$	2.97												
$28 \leq x < 42$	2.94												
$42 \leq x < 56$	2.91												
$56 \leq x$	2.56												
Criterion 4	Ozone Depletion Potential (ODP) of the refrigerant used for project air conditioning system is zero.												

Criterion 5	Plans to prevent release of refrigerants into the atmosphere at the time of air conditioning system removal are prepared for both project air conditioning system and the existing air conditioning system replaced by the project. In the case of replacing existing air conditioning system by project air conditioning system, execution of the prevention plan is checked at the time of verification, e.g. re-use of the refrigerant, in order to confirm that refrigerant used for the existing air conditioning system removed by the project is not released to the air.
-------------	--

E. Emission Sources and GHG types

Reference emissions	
Emission sources	GHG types
Electricity consumption by reference air conditioning systems	CO ₂
Project emissions	
Emission sources	GHG types
Electricity consumption by project air conditioning systems (include an indoor unit and an outdoor unit)	CO ₂

F. Establishment and calculation of reference emissions

F.1. Establishment of reference emissions

Reference emissions are calculated with electricity consumption of project air conditioning system, ratio of COPs of project/reference air conditioning system, and CO₂ emission factor for electricity consumed.

The COP of reference air conditioning system of non-inverter type is conservatively set *ex ante* in the following manner to ensure the net emission reductions.

- The reference COP, at a certain cooling capacity, is set at a maximum value in the respective cooling capacity range.

F.2. Calculation of reference emissions

$$RE_p = \sum_i \{ EC_{PJ,i,outdoor,p} \times (COP_{PJ,i,outdoor} \div COP_{RE,i}) \} \times EF_{elec}$$

RE_p	: Reference emissions during the period p [tCO ₂ /p]
$EC_{PJ,i,outdoor,p}$: Electricity consumption of outdoor unit of project air conditioning system i during the period p [MWh/p]
$COP_{PJ,i,outdoor}$: COP of outdoor unit of project air conditioning system i [-]
$COP_{RE,i}$: COP of reference air conditioning system i [-]
EF_{elec}	: CO ₂ emission factor for consumed electricity [tCO ₂ /MWh]
i	: Identification number of air conditioning system [-]

G. Calculation of project emissions

$$PE_p = \left(\sum_i EC_{PJ,i,outdoor,p} + EC_{PJ,indoor,p} \right) \times EF_{elec}$$

PE_p	: Project emissions during the period p [tCO ₂ /p]
$EC_{PJ,i,outdoor,p}$: Electricity consumption of outdoor unit of project air conditioning system i during the period p [MWh/p]
$EC_{PJ,indoor,p}$: Total electricity consumption of indoor units of project air conditioning system during the period p [MWh/p]
EF_{elec}	: CO ₂ emission factor for consumed electricity [tCO ₂ /MWh]
i	: Identification number of air conditioning system [-]

H. Calculation of emissions reductions

$$ER_p = RE_p - PE_p$$

ER_p	: Emissions reductions during the period p [tCO ₂ /p]
RE_p	: Reference emissions during the period p [tCO ₂ /p]
PE_p	: Project emissions during the period p [tCO ₂ /p]

I. Data and parameters fixed *ex ante*

The source of each data and parameter fixed *ex ante* is listed as below.

Parameter	Description of data	Source										
EF_{elec}	<p>CO₂ emission factor for consumed electricity.</p> <p>When captive power generation is not available at the project site, then the most recent Vietnamese national grid emission factor [EF_{grid}] available at the time of validation is applied as [EF_{elec}] and fixed for the monitoring period thereafter.</p> <p>When captive power generation is available at the project site, then [EF_{elec}] is conservatively selected as below and fixed for the monitoring period thereafter:</p> $EF_{elec} = \min(EF_{grid}, EF_{captive})$ $EF_{captive} = 0.8 \text{ tCO}_2/\text{MWh}^*$ <p>*The most recent emission factor available from CDM approved small scale methodology AMS-I.A at the time of validation is applied.</p>	<p>[EF_{grid}] Ministry of Natural Resources and Environment of Vietnam (MONRE), Vietnamese DNA for CDM unless otherwise instructed by the Joint Committee.</p> <p>[EF_{captive}] CDM approved small scale methodology: AMS-I.A</p>										
$COP_{RE,i}$	<p>COP of reference air conditioning system <i>i</i>, as indicated in Table 1. The values of cooling capacity and rated electricity consumption used in the calculation of COP are obtained from product catalogs, specification documents or website, hearing survey of major manufacturers in Vietnam.</p> <p>Table 1 : COP for Reference Air Conditioning System (COP_{RE,i})</p> <table border="1"> <thead> <tr> <th>Cooling Capacity [kW]</th> <th>Reference COP</th> </tr> </thead> <tbody> <tr> <td>$14 \leq x < 28$</td> <td>2.97</td> </tr> <tr> <td>$28 \leq x < 42$</td> <td>2.94</td> </tr> <tr> <td>$42 \leq x < 56$</td> <td>2.91</td> </tr> <tr> <td>$56 \leq x$</td> <td>2.56</td> </tr> </tbody> </table>	Cooling Capacity [kW]	Reference COP	$14 \leq x < 28$	2.97	$28 \leq x < 42$	2.94	$42 \leq x < 56$	2.91	$56 \leq x$	2.56	<p>Nominal value available on product catalogs, specification documents or websites, hearing survey.</p> <p>The default values are derived from the result of survey on COP of air conditioning system with non-inverter from manufacturers that have high market share.</p> <p>The default values should be revised if necessary from survey result which is conducted by JC or project participants every three years. The survey should prove the use of clear methodology.</p>
Cooling Capacity [kW]	Reference COP											
$14 \leq x < 28$	2.97											
$28 \leq x < 42$	2.94											
$42 \leq x < 56$	2.91											
$56 \leq x$	2.56											

$COP_{PJ,i,outdoor}$	COP of outdoor unit of project air conditioning system i . The value of cooling capacity and rated electricity consumption used in the calculation of COP prepared by manufacturer is applied.	Specifications of project air conditioning system for the quotation or factory acceptance test data by manufacturer.
----------------------	--	--