

Joint Crediting Mechanism Approved Methodology VN_AM013
“Energy saving by introduction of high-efficiency double suction volute pumps in water supply system”

A. Title of the methodology

Energy saving by introduction of high-efficiency double suction volute pumps in water supply system, Version 01.0

B. Terms and definitions

Terms	Definitions
<i>Double suction volute pump</i>	A pump with a double-suction impeller which has a double suction flow path in upstream and a double volute flow path in downstream.
<i>Pump efficiency</i>	Ratio of water horsepower output from the pump to the shaft horsepower input for the pump, which is expressed in percentage (%) and is calculated by dividing water horsepower output (kW) by shaft horsepower input (kW).

C. Summary of the methodology

Items	Summary
<i>GHG emission reduction measures</i>	High-efficiency double suction volute pump is introduced in water supply system to save energy, which leads to GHG emission reductions.
<i>Calculation of reference emissions</i>	Reference emissions are GHG emissions from power consumption by reference pumps, calculated with the monitored power consumption of project pumps, ratio of pump efficiency of reference/project pumps and CO ₂ emission factor for consumed electricity.
<i>Calculation of project emissions</i>	Project emissions are GHG emissions from power consumption by project pumps, calculated with the monitored power

	consumption of project pumps and CO ₂ emission factor for consumed electricity.
<i>Monitoring parameters</i>	<ul style="list-style-type: none"> ● Electricity consumption of project pumps ● The amount of fuel consumption and the amount of electricity generated by captive power, where applicable

D. Eligibility criteria

This methodology is applicable to projects that satisfy all of the following criteria.

Criterion 1	Double suction volute pump(s) with efficiency of more than 80% at a condition for operational use is installed for water supply system at a water treatment plant.
Criterion 2	Project pump uses environmental friendly paints such as paints with 0.1% or less lead, cadmium and tar during the production process.

E. Emission Sources and GHG types

Reference emissions	
Emission sources	GHG types
Electricity consumption by reference pumps	CO ₂
Project emissions	
Emission sources	GHG types
Electricity consumption by project pumps	CO ₂

F. Establishment and calculation of reference emissions

F.1. Establishment of reference emissions

Reference emissions are calculated with the monitored power consumption of project pumps, ratio of pump efficiency of reference/project pumps and CO₂ emission factor for consumed electricity.

The pump efficiency of reference pump is conservatively set as a default value in the following manner to ensure the net emission reductions.

Pump efficiencies for high-efficiency double suction volute pump are determined in the Japanese Industrial Standard JIS B 8322 “Double suction volute pumps” based on the collected

data of high-efficiency double suction volute pumps actually marketed in Japan. Application of those pump efficiencies as default values for reference pumps in consideration of pump efficiency commonly observed in Viet Nam ensures conservativeness and the net emission reductions in this methodology.

F.2. Calculation of reference emissions

$$RE_p = \sum_i \{ EC_{PJ,i,p} \times (\eta_{PJ,i} \div \eta_{RE,i}) \} \times EF_{elec}$$

Where

RE_p	Reference emissions during the period p [tCO ₂ /p]
$EC_{PJ,i,p}$	Power consumption of project pump i during the period p [MWh/p]
$\eta_{PJ,i}$	Pump efficiency of project pump i at a condition for operational use [%]
$\eta_{RE,i}$	Pump efficiency of reference pump i [%]
EF_{elec}	CO ₂ emission factor for consumed electricity [tCO ₂ /MWh]
i	Identification number of pump [-]

G. Calculation of project emissions

$$PE_p = \sum_i (EC_{PJ,i,p} \times EF_{elec})$$

Where

PE_p	Project emissions during the period p [tCO ₂ /p]
$EC_{PJ,i,p}$	Power consumption of project pump i during the period p [MWh/p]
EF_{elec}	CO ₂ emission factor for consumed electricity [tCO ₂ /MWh]
i	Identification number of pump [-]

H. Calculation of emissions reductions

$ER_p = RE_p - PE_p$	
<i>Where</i>	
ER_p	Emission reductions during the period p [tCO ₂ /p]
RE_p	Reference emissions during the period p [tCO ₂ /p]
PE_p	Project emissions during the period p [tCO ₂ /p]

I. Data and parameters fixed *ex ante*

The source of each data and parameter fixed *ex ante* is listed as below.

Parameter	Description of data	Source																																
$\eta_{PJ,i}$	Pump efficiency of project pump i at a condition for operational use [%]	Specifications of project pump i prepared for the quotation or factory acceptance test data by manufacturer.																																
$\eta_{RE,i}$	<p>Pump efficiency of reference pump i [%]</p> <p>$\eta_{RE,i}$ is selected from the default values in the following table in line with the capacity of project pump i. (“x” in the table denotes capacity per unit.)</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Capacity (m³/min)</td> <td>$x \leq 2$</td> <td>$2 < x \leq 3$</td> <td>$3 < x \leq 4$</td> <td>$4 < x \leq 5$</td> </tr> <tr> <td>$\eta_{RE,i}$</td> <td>70.5</td> <td>73.0</td> <td>74.0</td> <td>74.5</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Capacity (m³/min)</td> <td>$5 < x \leq 6$</td> <td>$6 < x \leq 8$</td> <td>$8 < x \leq 10$</td> <td>$10 < x \leq 15$</td> </tr> <tr> <td>$\eta_{RE,i}$</td> <td>75.0</td> <td>75.5</td> <td>76.0</td> <td>76.5</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Capacity (m³/min)</td> <td>$15 < x \leq 20$</td> <td>$20 < x \leq 30$</td> <td>$30 < x \leq 40$</td> </tr> <tr> <td>$\eta_{RE,i}$</td> <td>77.0</td> <td>78.0</td> <td>78.5</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Capacity (m³/min)</td> <td>$40 < x \leq 50$</td> <td>$50 < x \leq 60$</td> <td>$60 < x \leq 70$</td> </tr> </table>	Capacity (m ³ /min)	$x \leq 2$	$2 < x \leq 3$	$3 < x \leq 4$	$4 < x \leq 5$	$\eta_{RE,i}$	70.5	73.0	74.0	74.5	Capacity (m ³ /min)	$5 < x \leq 6$	$6 < x \leq 8$	$8 < x \leq 10$	$10 < x \leq 15$	$\eta_{RE,i}$	75.0	75.5	76.0	76.5	Capacity (m ³ /min)	$15 < x \leq 20$	$20 < x \leq 30$	$30 < x \leq 40$	$\eta_{RE,i}$	77.0	78.0	78.5	Capacity (m ³ /min)	$40 < x \leq 50$	$50 < x \leq 60$	$60 < x \leq 70$	<p>Specifications of project pump i prepared for the quotation or factory acceptance test data by manufacturer.</p> <p>The default values $\eta_{RE,i}$ are derived from the Japanese Industrial Standard JIS B 8322 “Double suction volute pumps”. Revision of default values $\eta_{RE,i}$ should be considered if JIS B 8322 is revised.</p>
Capacity (m ³ /min)	$x \leq 2$	$2 < x \leq 3$	$3 < x \leq 4$	$4 < x \leq 5$																														
$\eta_{RE,i}$	70.5	73.0	74.0	74.5																														
Capacity (m ³ /min)	$5 < x \leq 6$	$6 < x \leq 8$	$8 < x \leq 10$	$10 < x \leq 15$																														
$\eta_{RE,i}$	75.0	75.5	76.0	76.5																														
Capacity (m ³ /min)	$15 < x \leq 20$	$20 < x \leq 30$	$30 < x \leq 40$																															
$\eta_{RE,i}$	77.0	78.0	78.5																															
Capacity (m ³ /min)	$40 < x \leq 50$	$50 < x \leq 60$	$60 < x \leq 70$																															

	(m ³ /min)				
	$\eta_{RE,i}$	79.0	79.5	80.0	
EF_{elec}	<p>CO₂ emission factor of consumed electricity.</p> <p>When project pumps consume only grid electricity or captive electricity, the project participant applies the CO₂ emission factor respectively.</p> <p>When project pumps may consume both grid electricity and captive electricity, the project participant applies the CO₂ emission factor with lower value.</p> <p>[CO₂ emission factor]</p> <p>For grid electricity: The most recent value available from the source stated in this table at the time of validation</p> <p>For captive electricity, it is determined based on the following options:</p> <p>a) Calculated from its power generation efficiency ($\eta_{elec,CG}$ [%]) obtained from manufacturer's specification</p> <p>The power generation efficiency based on lower heating value (LHV) of the captive power generation system from the manufacturer's specification is applied;</p> $EF_{elec} = 3.6 \times \frac{100}{\eta_{elec,CG}} \times EF_{fuel,CG}$ <p>b) Calculated from measured data</p> <p>The power generation efficiency calculated from monitored data of the amount of fuel input for power generation ($FC_{PJ,CG,p}$) and the amount of</p>				<p>[Grid electricity]</p> <p>Ministry of Natural Resources and Environment of Vietnam (MONRE), Vietnamese DNA for CDM unless otherwise instructed by the Joint Committee.</p> <p>[Captive electricity]</p> <p>For the option a)</p> <p>Specification of the captive power generation system provided by the manufacturer ($\eta_{elec,CG}$ [%]).</p> <p>CO₂ emission factor of the fossil fuel type used in the captive power generation system ($EF_{fuel,CG}$ [tCO₂/GJ])</p> <p>For the option b)</p> <p>Generated and supplied electricity by the captive power generation system ($EG_{PJ,CG,p}$ [MWh/p]).</p> <p>Fuel amount consumed by the captive power generation system ($FC_{PJ,CG,p}$ [mass or volume/p]).</p> <p>Net calorific value</p>

	<p>electricity generated ($EG_{PJ,CG,p}$) during the monitoring period p is applied. The measurement is conducted with the monitoring equipment to which calibration certificate is issued by an entity accredited under national/international standards;</p> $EF_{elec} = FC_{PJ,CG,p} \times NCV_{fuel,CG} \times EF_{fuel,CG} \times \frac{1}{EG_{PJ,CG,p}}$ <p>Where: $NCV_{fuel,CG}$: Net calorific value of fuel consumed by the captive power generation system [GJ/mass or volume]</p> <p>Note: In case the captive electricity generation system meets all of the following conditions, the value in the following table may be applied to EF_{elec} depending on the consumed fuel type.</p> <ul style="list-style-type: none"> ● The system is non-renewable generation system ● Electricity generation capacity of the system is less than or equal to 15 MW <table border="1" data-bbox="453 1375 986 1545"> <thead> <tr> <th>fuel type</th> <th>Diesel fuel</th> <th>Natural gas</th> </tr> </thead> <tbody> <tr> <td>EF_{elec}</td> <td>0.8^{*1}</td> <td>0.46^{*2}</td> </tr> </tbody> </table> <p>*1 The most recent value at the time of validation is applied. *2 The value is calculated with the equation in the option a) above. The lower value of default effective CO₂ emission factor for natural gas (0.0543 tCO₂/GJ), and the most efficient value of default efficiency for off-grid gas turbine systems (42%) are applied.</p>	fuel type	Diesel fuel	Natural gas	EF_{elec}	0.8 ^{*1}	0.46 ^{*2}	<p>($NCV_{fuel,CG}$ [GJ/mass or volume]) and CO₂ emission factor ($EF_{fuel,CG}$ [tCO₂/GJ]) of the fuel consumed by the captive power generation system in order of preference:</p> <ol style="list-style-type: none"> 1) values provided by the fuel supplier; 2) measurement by the project participants; 3) regional or national default values; 4) IPCC default values provided in tables 1.2 and 1.4 of Ch.1 Vol.2 of 2006 IPCC Guidelines on National GHG Inventories. Lower value is applied. <p>[Captive electricity with diesel fuel] CDM approved small scale methodology: AMS-I.A.</p> <p>[Captive electricity with natural gas] 2006 IPCC Guidelines on National GHG Inventories for the source of EF of natural gas. CDM Methodological tool "Determining the baseline efficiency of thermal or electric energy</p>
fuel type	Diesel fuel	Natural gas						
EF_{elec}	0.8 ^{*1}	0.46 ^{*2}						

		generation systems version02.0" for the default efficiency for off-grid power plants.
--	--	--

History of the document

Version	Date	Contents revised
01.0	29 August 2018	Decision by the Joint Committee Initial approval.